

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 512858D

Manufacturer: Provia Door, Inc.
2150 State Route 39
Sugarcreek, OH 44681

Product Line: Fiberglass Fixed Sidelite Window

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02144 Revision B, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: NCTL 110-15650-4 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 55.0 psf
Water penetration resistance 8.25psf
3. Report No.: NCTL 110-13337-1 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E330
Design pressure: $+48.0/-52.0$ psf
4. Report No.: NCTL 110-15650-1 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E330
Design pressure: ± 55.0 psf
Water penetration resistance 8.25psf
5. Anchor calculations, report number 512858-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: $+48.0/-52.0$ psf
- Unit size: 17 1/4" x 97 1/2"
- Units must be glazed per ASTM E 1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Composite.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02144 Revision B.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

