

L. Roberto Lomas P.E.

208 7th Avenue
Indialantic, FL 32903
434-688 - 0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515568

Manufacturer: Magnolia Window & Door
1000 Pyratich Drive
Baldwin, GA 30511

Product Line: 400 PVC Fixed over Single Hung Window Non-Impact 32" x 96" and 48" x 96"

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-04172, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: CCL 24-080 signed by Wesley Wilson
Construction Consulting Laboratory, Carrollton, TX
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 30.08 psf (48" x 96" unit)
 ± 40.1 psf (32" x 96" unit)
Water penetration resistance: 6.06psf
3. Anchor calculations with comparative analysis, report number 515568-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid vinyl PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-04172.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

