

*L. Roberto Lomas P.E.*

400 S Palm Ave  
Indialantic, FL 32903  
434-688-0609

## Engineering Evaluation Report

Report No.: 512724C

**Manufacturer:** Peachtree Protective Covers, Inc.  
1477 Rosedale Drive  
Hiram, GA 30141

**Product Line:** ACM Wall Panel System Dry-Joint

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02011, Revision C, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test Report No.: B7289.01-109-44 signed and sealed by Michael D. Stremmel, P.E.  
Architectural Testing, Inc., York, PA  
ASTM E330  
Design pressure: +75.0/-60.0psf  
Water penetration resistance 15.0psf
3. Anchor calculations, report number 512724-1C, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: +75.0/-60.0psf
- Overall panel size: 32 Square feet.
- Minimum panel thickness: 0.150" (0.02" min. aluminum skin)
- This product is not rated to be used in the HVHZ.
- This product has not been evaluated for wind borne debris protection.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02011, Revision C.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

