

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: ZIPUP UNDERDECK SYSTEM

MANUFACTURER: MP GLOBAL PRODUCTS, LLC
34020 JAMES J POMPO
FRASER MI 48026

To all concerned,

The ZipUp Underdeck System, manufactured by MP Global Products, LLC is a Rigid PVC panel system designed for use in soffits, awnings, and canopies. It has been tested per Florida Building Code protocols TAS 202 (structural only) and TAS 203 by Architectural Testing, Inc, with results shown in test report # B4275.01-450-18.

Technical Documentation:

1. Drawing "Zip1", dated 12/10/25, signed and sealed by Scott Wolters, PE.
2. ATI Test Report B4275.01-450-18, signed and sealed by Vinu J. Abraham, PE.
3. ZipUp Underdeck System Calculations, signed and sealed by Scott Wolters, PE


I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapters 16 and 26 specifically, for use outside the HVHZ.


Limitations: This product is not impact resistant, and is not designed for use as part of the building envelope. It is not approved for use in the HVZ.

Overall Dimensions:

Maximum panel width:	12 1/8" (Single Panel)
Maximum overall width:	Unlimited
Maximum panel length:	192"
Maximum design pressure:	+/- 29.12 psf

Thank you,


Scott Wolters
FL PE# 62354
DEC 10 2025



Digitally signed
by Scott Wolters
Date: 2025.12.10
00:22:17 -05'00'

SPECIALIZING IN MIAMI-DADE AND FLORIDA PRODUCT APPROVALS FOR ROOFING & GLAZING PRODUCTS