



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 16585

Date: 08/12/2020

Detailed Product Description:

Manufacturer: MULIA INC.

Manufacturer Address: 100 BUSINESS CENTER DR. #12, ORMOND BEACH, FL 32174

Model Name: SERIES LW GLASS BLOCK VINYL FRAMED WINDOW

Maximum Load: +110 PSF, -110 PSF (Non-Impact)

Installation Drawings # W12-56

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <u> </u> Yes <u> X </u> No					
Mandatory Tests (Tested in accordance with AAMA/WDMA/CSA 101/IS2/A440)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Architectural Testing, Inc.	05/08/2013	C7461.01-401-44	Shawn G. Collins, P.E.
ASTM 547	Water Penetration	Architectural Testing, Inc.	05/08/2013	C7461.01-401-44	Shawn G. Collins, P.E.
ASTM E330	Uniform Static Air	Architectural Testing, Inc.	05/08/2013	C7461.01-401-44	Shawn G. Collins, P.E.
ASTM F588	Forced Entry	Architectural Testing, Inc.	05/08/2013	C7461.01-401-44	Shawn G. Collins, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 9/1/20