

Evaluation Report 884D
September 16, 2026

Product Description: Series 4000 Aluminum Fixed Window with Nailing Fin, Non-Impact, 48"x67" unit size O, or 110" x 23" unit size O/O with "Fake Mull" Impost, in concrete/masonry wall construction with externally applied 2x wood bucks

Manufacturer: Custom Window Systems, Inc. 1900 SW 44th Ave, Ocala, FL 34474

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 9th Edition (2026) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing CWS-884D, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3660-1A, -2A, and -3A, from National Certified Testing Laboratories, Orlando, FL signed and sealed by Gerard J. Ferrara, P.E., with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-11/17
- 4) Supplemental Calculations to support CWS-884D, signed and sealed by Lucas A. Turner, P.E.


Installation: Units must be installed according to approval document CWS-884D.

Limitations of Use: This product:

- May be used up to sizes of 48"x67" unit size O, or 110" x 23" unit size O/O with "Fake Mull" Impost
- Achieves design pressures as shown in CWS-884D
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires glass types as shown in CWS-884D

Coastal Compliance:

- Fastener criteria other than described below shall be in accordance with CWS-884D.
- Fasteners used in locations less than or equal to 300 ft from a saltwater coastline, where any portion of the fastener is located to the exterior of the Water-Resistive Barrier (WRB) of the wall construction, or is a Weather-Exposed Surface, or as otherwise required by the




Lucas Turner
2026.09.18
14:23:31 -05'00'
9/16/2026
Lucas A. Turner, P.E.
FL PE #58201

Authority Having Jurisdiction (AHJ), shall meet the criteria of FBC Sect. 1711.1.1.1 or RBC Section R332.1.1.1 as applicable. For wood installation substrates, requires stainless steel, 100 ksi min. ult. (cold

- Fasteners used in locations less than or equal to 300 ft from a saltwater coastline, where the entire fastener is located to the interior of the WRB of the wall construction, or determined by the Registered Design Professional or AHJ for the project to be located within the Unconditioned Interior of the wall construction, or as otherwise required by the AHJ, shall meet the criteria of FBC Sect. 1711.1.1.2 or RBC Section R332.1.1.2 as applicable.
- Fasteners used in locations greater than 300 ft and up to 3000 ft from a saltwater coastline, in any Exterior/Interior location of the wall construction, or as otherwise required by the AHJ, shall meet the criteria of FBC Sect. 1711.1.1.2 or RBC Section R332.1.1.2 as applicable.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Custom Window Systems or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



9/16/2026
Lucas A. Turner, P.E.
FL PE #58201