

Product Evaluation Report

Report No.: FL-16853.12

Date: June 30, 2015

Product Category	Sub Category	Manufacturer	Product Name
Windows	Horizontal Slider	Doers Window Manufacturing, LLC 4901 Oak Fair Blvd Tampa, FL 33610 (813) 626-6000	9500-3 Slider XO Impact Rated - HVHZ w/ Flange

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Doers Window Manufacturing, LLC, based on Rule Chapter No. 61G20-3, Method 1A of the State of Florida Product Approval, Dept. of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product anchoring drawing has been evaluated and is in compliance with the 5th Edition (2014) Florida Building Code (FBC) including the "High Velocity Hurricane Zone" (HVHZ). See the Certification Agency Certificate for sizes, specifications & ratings.
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in the "HVHZ", this product complies with Section 1626 of the FBC and does not require an impact resistant covering.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-16853.12 require further engineering analysis by a licensed engineer or registered architect.
6. See drawing FL-16853.12 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|--|---|--|
| 1. Test Report No.
ATI D0238.03-401-44
ATI D0238.04-401-44 | Test Standard
TAS 201, 202, 203-94
ASTM E 1886-05 / E 1996-05 | Testing Laboratory
Architectural Testing, Inc.
Architectural Testing, Inc. | Signed by
Shawn G. Collins, P.E.
Shawn G. Collins, P.E. |
| 2. Miami Dade NOA
14-0423.16 | Materials Testing
Saflex® PVB Interlayer (Eastman Chemical Co.) | | |
| 3. Drawing No.
No. FL-16853.12 | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Calculations
Anchoring | Prepared by
RW Building Consultants, Inc. (CA #9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |



Lyndon F. Schmidt, P.E.
FL PE No. 43409
9/17/2015