L. Roberto Lomas P.E.
208 7th Ave
Indialantic, FL 32903
434-688-0609
rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513056B

Manufacturer: MIM Risk Solutions, Inc.
1056 NE Pine Island Rd #H-W
Cape Coral, FL 33909

Product Line: Direct Wall Aluminum Roll Shutter-In-A-Box Aluminum Roll-up Shutter System, HVHZ

Compliance:
The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:
1. Approval document: drawing number 08-03141 revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL 210-3928-01 signed and sealed by Gerard J. Ferrara P.E.
   National Certified Testing Laboratories, Orlando, FL
   TAS 201/ TAS 203
   Large Missile Impact Test, Level D, Wind Zone 4
   Cyclic Pressure loading, ±40.0psf design pressure
   TAS 202
   Uniform Static Air Pressure, ±40.0psf design pressure
3. Anchor calculations, report number 513056-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:
- Design pressure: Refer to installation drawing
- Unit size: Refer to installation drawing
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Aluminum.

Installation:
Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03141 revision B.

Certification of Independence:
Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E.
FL No.: 62514
04/01/2024