

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

GARAGE DOOR EVALUATION REPORT

Garage Door No.:	IBC-1309-150-15-I		Test Date:	3/23-3/25/2015		Project No.:	14-006			
Design Pressures:	+32.6 psf, -38.3 psf		Report Date:	11/3/2020		Model #	1350			
Test Pressures:	+48.9 psf, -57.5 psf		Test Location:	American Test Lab, Inc., Brevard, NC						
ASCE 7-16 Criteria:	Up to 5 Feet of Door Width in Zone 5; Roof Slope ≤ 10°; Enclosed Building									
	Exp. B, 30' MRH		Exp. C, 15' MRH		Exp. C, 25' MRH		Exp. D, 15' MRH		Exp. D, 25' MRH	
	195 mph		177 mph		168 mph		160 mph		154 mph	

Reference Test Report and Drawing:

- American Test Lab, Inc. report number ATLNC-0323.02-15 dated 4/21/2015
- Entrematic Drawing number IBC-1309-150-15-I dated 3/3/2015

Description of Test Specimen:

9'-2"x8'-0" Amarr Model 1350, 27 ga steel garage door as shown in drawing IBC-1309-150-15-I.

Test Standards and Report Conclusion:

The above referenced Test Report states the following:

- The tests were conducted in accordance with ASTM E1886-05, E1996-09, F588-07; and ANSI / DASMA 115-2005.
- The weight of the missile used for the Large Missile Impact Test was 9.3 lbs.
- All tests were conducted with no deviations.
- The test was witnessed and certified by David Johnson, PE, 1656 Calvert Road, Brevard, NC (FL PE #00061915)
- American Test Lab is accredited by IAS, Certification #TL-423.


Summary:

The 9'-2"x8'-0" Amarr Model 1350 as described on drawing IBC-1309-150-15-I meets or exceeds the testing criteria as described above. By comparison to the construction of the 9'-2"x8'-0" Amarr Model 1350, the following doors also meet or exceed the above testing criteria, when constructed in accordance with drawing IBC-1309-150-15-I:

- 9'-2" x 8' Amarr Model 2700 doors (which are 2" thick in lieu of 1 3/8" thick)
- Amarr Model 1350 and 2700 doors with widths up to 9'-2" and heights up to 14'-0"

To the best of my knowledge, the above garage door conforms to the requirements of the Florida Building Code 7th Edition (2020).

Submitted By:



STRUCTURAL SOLUTIONS, P.A.* (*Florida: dba Structural Solutions of North Carolina, Inc., Firm #29412)

Thomas L. Shelmerdine, PE (NC PE #14654; Florida PE #0048579)

5921-G West Friendly Avenue ■ Greensboro, North Carolina 27410 ■ (336) 856-2686 ■ Fax (336) 856-2687 ■ NC Firm #C-1096