

**PRODUCT EVALUATION REPORT**  
**RULE 61G20-3 – EVALUATION REPORT FROM A PROFESSIONAL ENGINEER**  
**Report Number: 26-169**

---

- 1- Date:** 08/25/2026
- 2- Manufacturer:** Croci North America  
11600 Adelmo Lane – Fort Myers  
Florida, 33966
- 3- Product Name:** 26-169 – ES55 SUP Rolling Door  
Large / Level D Impact Rated
- 4- Evaluation Entity:** Florida Professional Engineer  
Pedro Paulo M. De Figueiredo – PE 52609  
631 Seaport Blvd.  
Cape Canaveral – Florida 32920

**5- Statement of Compliance:** This product evaluation report is being issued per Rule 61G20-3 of the Florida Department of Business and Professional Regulation. The products covered by this report are compliant with the Florida Building Code 2026 – 9<sup>th</sup> edition, not limited to the following standards: ASTM E330; TAS 201, 202, 203, Aluminum Design Manual 2020 and AWC NDS 2024.

**6- Product Description:** This product is an Aluminum Rolling Door designed, constructed and erected to easily enclose an area, providing protection from hurricane force winds and large missile windborne debris within the allowable designed pressures and limitations stated in this approval. Specification for design, fabrication and installation is found in drawings 26-169.

## 7- Technical Documentation:

**7.1- Approval Document:** Drawing number 26-169 prepared by PPMF, Inc. on 08/25/2026 sheets 1 through 10 of 10, titled "ES 55 SUP" Rolling Door, signed, and sealed by Pedro De Figueiredo, PE.

**7.2- Test Reports** – Product has been tested at Fenestration Testing Laboratory, Inc. with report FTL 7241 signed by Jorge Naya Jr. PE 20778. Product has been tested under protocols TAS 201, 202 and 203 as well as ASTM E330, E1996 and E1886.

**7.3- Calculations:** None for this code cycle

## 8- Limitation and Conditions of use:

Product to be manufactured, designed, and installed as per drawing specifications 26-169, prepared by PPMF Inc dated 08/25/2026 and signed and sealed by Pedro De Figueiredo, PE.

## 9- Others:

Product to be used as an Operable Impact Protective System.  
Category selection as per the Florida Building Code

Pedro  
Figueiredo

Digitally signed by  
Pedro Figueiredo  
Date: 2026.08.28  
13:50:33 -04'00'



Pedro De Figueiredo  
Fl. P.E. License: 52609  
System ID: 2504