

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: WOOD EUROPEAN SERIES GLAZED OUTSWING FRENCH DOORS (TEAK)

MANUFACTURER: LUXBAUM WINDOWS & DOORS
2400 CENTREPARK WEST DRIVE, SUITE 150
WEST PALM BEACH, FL 33409

To all concerned,

The Luxbaum Wood European Series Glazed Outswing French Door, manufactured by Luxbaum Windows & Doors, is a glazed Teak wood door set in a Teak frame. The door has been tested per TAS 201, 202, and 203 by Intertek. with results shown in test report H6254.03-450-18 R0.

Technical Documentation:

1. Drawing "EURO DOOR-TEAK", signed and sealed by Scott Wolters, PE.
2. Intertek test report H6254.03-450-18 R0, signed and sealed by Vinu Abraham, PE.
3. Supplemental calculations to support "EURO DOOR-TEAK", signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 6th Edition (2017) Florida Building Code generally, and chapters 10, 11, 16, 23, and 24 specifically, including the HVHZ provisions.

Limitations: This door is approved for use inside and outside of the HVHZ. It is large and small impact resistant. Shutters are not required.

Overall Dimensions:

Maximum Frame Height:	Varies – See Elevations on Sheets 1-3.
Maximum Frame Width:	Varies – See Elevations on Sheets 1-3.
Maximum Design Pressure:	+65/-70 psf

Glazing Options:

1 1/8" Insulated Laminated
1/4" Annealed
0.180" SGP Interlayer+
1/4" Annealed
1/2" Air Space
1/4" Tempered

3/4" (min) Marine Grade Plywood

+ I have evaluated the SentryGlas interlayer (NOA# 14-0916.11) referenced above and find that it complies with the requirements of the 6th Edition (2017) Florida Building Code for use in this product.

Locks:

AGB Multi-Point Locks
with Siegenia Strike Plates

Hinges:

La Florida-Inox, 21" Max. O.C.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
DEC 16 2017

