



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.

Suite 338

Dania Beach, FL 33004

954.399.8478 PH

954.744.4738 FX

contact@buildingdrops.com

Product Evaluation Report

of

**La Cantina Doors, Inc.
Contemporary Clad Sliding Door
(NON-HVHZ)(NON-IMPACT)**

for

Florida Product Approval

Report No. 6972

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Exterior Doors
Sub – Category:	Sliding Exterior Door Assemblies
Product:	Contemporary Clad Sliding Door (Non-HVHZ)(Non-Impact)
Material:	Wood
Product Dimensions:	See Installation Instructions, LCD013

Prepared for:

**La Cantina Doors, Inc.
1875 Ord Way
Oceanside, CA. 92056**

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date: 07/10/2020

Contents:

Evaluation Report Pages 1 – 3

Digitally signed by Hermes F Norero
Reason: I am approving this document
Date: 2020.10.23 15:19:35 +02'00'



Hermes F. Norero, P.E.
Florida P.E. No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 07/10/2020

Report No: 6972

Manufacturer: La Cantina Doors, Inc.

Product Category: Exterior Doors

Product Sub-Category: Sliding Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: Contemporary Clad Sliding Door
(NON-HVHZ)(NON-IMPACT)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **La Cantina Doors, Inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions on **LCD013**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering.
4. Site conditions that deviate from the details of Installation Instructions **LCD013** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions on **LCD013** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 07/10/2020

Report No: 6972

Quality Assurance:

The manufacturer has demonstrated compliance of door products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation & Management Institute, Inc.** (FBC Organization #QUA1789)

Performance Standards:

The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-11

Referenced Data:

1. Product Testing performed by **Fenestration Testing Laboratory, Inc.**
(FBC Organization #TST9341)
Report #: T15-048 Report Date: 11/09/15
2. Quality Assurance
National Accreditation & Management Institute, Inc.
(FBC Organization #QUA1789)

Installation Method:

Please refer to Installation instructions, **LCD013**, for anchor methods, selection, spacing, edge distances, embedments and further details of installation.

Design Pressure:

Please refer to Installation instructions, **LCD013**, for sizes, configurations and design pressures.