

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

GARAGE DOOR EVALUATION REPORT

Garage Door No.:	IBC-3614-104-63		Test Date:	8/1/2014		Project No.:	14-079			
Design Pressures:	+15.1 psf, -17.2 psf		Report Date:	11/2/2020		Model #	3550			
Test Pressures:	+22.7 psf, -25.8 psf		Test Location:	Entrematic, Winston-Salem, NC						
ASCE 7-16 Criteria:	Up to 5 Feet of Door Width in Zone 5; Roof Slope ≤ 10°; Enclosed Building									
	Exp. B, 30' MRH		Exp. C, 15' MRH		Exp. C, 25' MRH		Exp. D, 15' MRH		Exp. D, 25' MRH	
	135 mph		122 mph		116 mph		111 mph		106 mph	

Reference Test Report and Drawing:

- Structural Solutions, P.A.* Garage Door Static Pressure Test Report for IBC-3614-104-63 dated 11/02/2020
- Entrematic Drawing number IBC-3614-104-63 dated 8/12/2014

Description of Test Specimen:

14'-2"x8'-0" Model 3550, 0.050 inch aluminum garage door as shown in drawing IBC-3614-104-63.

Test Standards and Report Conclusion:

The above referenced Test Report states the following:

- The tests were conducted in accordance with ASTM E330-14 and DASMA 108-05.
- The test was witnessed and certified by Thomas L. Shelmerdine, PE (FL PE# 48579)
- The test facility at Entrematic is accredited by the American Association for Laboratory Accreditation, Certificate #2595.01.


Summary:

The 14'-2"x8'-0" Model 3550 as described on drawing IBC-3614-104-63 meets or exceeds the testing criteria as described above. By comparison to the construction of the 14'-2"x8'-0" Model 3550, the following doors also meet or exceed the above testing criteria, when constructed in accordance with drawing IBC-3614-104-63:

- Model 3550 doors with widths up to 14'-2" and heights up to 24'-0"

To the best of my knowledge, the above garage door conforms to the requirements of the Florida Building Code 7th Edition (2020).

Submitted By:



STRUCTURAL SOLUTIONS, P.A.* (*Florida: dba Structural Solutions of North Carolina, Inc., Firm #29412)

Thomas L. Shelmerdine, PE (NC PE #14654; Florida PE #0048579)

5921-G West Friendly Avenue ■ Greensboro, North Carolina 27410 ■ (336) 856-2686 ■ www.sspa.biz ■ NC Firm #C-1096