

Manufacturer: Solar Innovations
31 Roberts Road
Pine Grove, PA 17963

Product Line: Series SI8000 G-3 Multi Track 90° No Post Aluminum Sliding Glass Door - Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02496 Revision E, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: NCTL 110-17649-1 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E330 Design pressure: +55.14/-60.15psf
Water penetration resistance: 8.0psf
3. Report No.: NCTL 110-17649-2 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, ±60.0psf design pressure
4. Test report No.: NCTL 110-15389-1 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E 330: Design Pressure: ± 65.0psf
ASTM E 331: Water Penetration: 20.0psf
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, ±65.0psf design pressure
5. Report No.: NCTL 110-15389-2 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±65.16psf
Water penetration resistance 20.0psf
6. Anchor calculations, report number 513260-2D, prepared, signed and sealed by Luis Roberto Lomas P.E.
7. Comparative analysis, report number 513260-3, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±60.0psf
- Approved configurations: Unlimited number of panels in unlimited configurations are approved as long as individual panel area does not exceed 48.05 ft² and uses vertical conditions as shown in approval document.
- Units must be glazed per ASTM E1300 according with glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be rigid aluminum 6063-T5.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02496 Revision E.

When the product specified herein is installed within 3000 ft. of saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

