

Product Evaluation Report**Report No.: FL-17347.18****Date: August 10, 2023**

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Plastpro, Inc. 5200 West Century Blvd. Los Angeles, CA 90045 Phone 440.969.9773	Opaque Fiberglass Doors Doubles w/ or w/out Sidelites Inswing / Outswing - "Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Plastpro, Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code structural requirements excluding the "High Velocity Hurricane Zone".
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and excludes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-17347.18 require further engineering analysis by a licensed engineer or registered architect
6. See drawing FL-17347.18 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|--|---|--|---|
| <p>1. <u>Test Report No.</u>
TEL 01393551</p> <p>TEL 01390242
TEL 01390242-IC
ETC 10-209-24714.1
TEL 01311960</p> | <p><u>Test Standard</u>
ASTM E330-14, E331-00,
E1886-13a, 1996-14a
ASTM E330-02, E331-00
ASTM E 1886/1996-02
ASTM E 330-02 & E 1886/1996-02
ASTM E330-02/E331-00/
E1886-05/1996-09</p> | <p><u>Testing Laboratory</u>
Testing Evaluation Laboratories, Inc.</p> <p>Testing Evaluation Laboratories, Inc.
Testing Evaluation Laboratories, Inc.
ETC Laboratories
Testing Evaluation Lab.,Inc.</p> | <p><u>Signed by</u>
V.K. Wright</p> <p>Lyndon F. Schmidt, P.E.
Lyndon F. Schmidt, P.E.
Mark Sennett
V. K. Wright</p> |
| <p>2. <u>Drawing No.</u>
No. FL-17347.18</p> | <p><u>Prepared by</u>
RW Building Consultants, Inc. (#9813)</p> | <p><u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E.</p> | |
| <p>3. <u>Miami-Dade NOA No.</u>
21-0216.01</p> | <p><u>Materials Testing</u>
Saflex PVB Interlayer (Eastman Chemical Co.)</p> | | |
| <p>4. <u>Calculations</u>
Anchoring
ASTM E 1300 Glass Load</p> | <p><u>Prepared by</u>
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813)</p> | <p><u>Signed & Sealed by</u>
Lyndon F. Schmidt, P.E.</p> | |
| <p>5. <u>Quality Assurance</u>
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Plastpro, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.</p> | | | |

Digitally signed by
Lyndon F Schmidt
Date: 2023.08.10
12:24:31 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-10-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA