

Engineering Evaluation Report - 5XMULLS-LM-CLIPPED

Prepared by:

A. Lynn Miller, P.E.
3400 Precision Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

PGT Industries, LLC
3400 Precision Drive
North Venice, FL 34275

Product Description:

Series 5400/5500 Impact-Resistant, Aluminum Mullions, (LM), FL-17519

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval Document: Drawing number 5XMULLS-LM-CLIPPED, signed and sealed by A. Lynn Miller, P.E.
2. Test Reports:
FTL-8168-8171, signed and sealed by Idalmis Ortega; Fenestration Testing Laboratories, Medley, FL
AAMA 450-10

Limitations and Conditions of use:

- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Material to be extruded Aluminum.
- Units must be installed in accordance with approval document.

