

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave.

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 513352B**

**Manufacturer:** Viwinco, Inc.  
Morgantown Business Park  
P.O. Box 499  
Morgantown, PA 19543

**Product Line:** Signature/Viwinco Casement Picture 72" x 72" – Non-Impact

**Compliance:**

The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02573, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI 78079.02-109-47-R1 signed by Michael D. Stremmel P.E.  
Architectural Testing Inc., York, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: ±50.0psf  
Water penetration resistance 12.11psf
3. Anchor calculations, report number 513352-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±50.0psf
- Maximum unit size: 72" x 72"
- Units must be glazed per ASTM E 1300
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

**Installation:**

Units must be installed in accordance with approval document, 08-02573.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

