

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

GARAGE DOOR EVALUATION REPORT

Garage Door No.:	IRC-1418-130-26-I		Test Date:		1/27-1/28/2015	Project No.:		14-148	
Design Pressures:	+25.1 psf, -28.4 psf		Report Date:		11/2/2020		Model #		1480
Test Pressures:	+37.7 psf, -42.6 psf		Test Location:		American Test Lab, Inc., Brevard, NC				
ASCE 7-16 Criteria:	Up to 5 Feet of Door Width in Zone 5; Any Roof Slope; Enclosed Building								
	Exp. B, 30' MRH		Exp. C, 15' MRH		Exp. C, 25' MRH		Exp. D, 15' MRH		Exp. D, 25' MRH
	168 mph		152 mph		145 mph		138 mph		133 mph

Reference Test Report and Drawing:

- American Test Lab, Inc. report number ATLNC-0127.01-14 dated 2/25/2015
- Entrematic Drawing number IRC-1418-130-26-I dated 12/8/2014

Description of Test Specimen:

18'-2"x8'-0" Amarr Model 1480, 27 ga steel garage door as shown in drawing IRC-1418-130-26-I.

Test Standards and Report Conclusion:

The above referenced Test Report states the following:

- The tests were conducted in accordance with ASTM E1886-05, E1996-09, F588-07; and ANSI / DASMA 115-2005.
- The weight of the missile used for the Large Missile Impact Test was 9.1 lbs.
- All tests were conducted with no deviations.
- The test was witnessed and certified by David Johnson, PE, 1656 Calvert Road, Brevard, NC (FL PE #00061915)
- American Test Lab is accredited by IAS, Certification #TL-423.


Summary:

The 18'-2"x8'-0" Amarr Model 1480 as described on drawing IRC-1418-130-26-I meets or exceeds the testing criteria as described above. By comparison to the construction of the 18'-2"x8'-0" Amarr Model 1480, the following doors also meet or exceed the above testing criteria, when constructed in accordance with drawing IRC-1418-130-26-I:

- Amarr Model 1480 doors with widths up to 18'-2" and heights up to 14'-0"

To the best of my knowledge, the above garage door conforms to the requirements of the Florida Building Code 7th Edition (2020).

Submitted By:



STRUCTURAL SOLUTIONS, P.A.* (*Florida: dba Structural Solutions of North Carolina, Inc., Firm #29412)

Thomas L. Shelmerdine, PE (NC PE #14654; Florida PE #0048579)

5921-G West Friendly Avenue ■ Greensboro, North Carolina 27410 ■ (336) 856-2686 ■ Fax (336) 856-2687 ■ NC Firm #C-1096