

*L. Roberto Lomas P.E.*

208 7<sup>th</sup> Ave

Indialantic, FL 32903

434-688-0609

rlomas@rlomaspe.com

## Engineering Evaluation Report

Report No.: 513351A

**Manufacturer:** Viwinco, Inc.  
Morgantown Business Park  
P.O. Box 499  
Morgantown, PA 19543

**Product Line:** S-Series Outswing Casement 36" x 72" – Non-Impact

**Compliance:**

The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02572 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ATI B6052.02-109-47 signed by Michael D. Stremmel P.E.  
Architectural Testing Inc., York, PA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: ±65.0psf  
Water penetration resistance 12.11psf
3. Anchor calculations, report number 513351-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: ±65.0psf
- Unit size: 36" x 72"
- Units must be glazed per ASTM E 1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02572 Revision A.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

