AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 17682
Date: 08/10/2026

Detailed Product Description:

Manufacturer: ALDORA ALUMINUM & GLASS PRODUCTS, INC.

Manufacturer Address: 4250 CORAL RIDGE DRIVE, SUITE 101. CORAL SPRINGS, FL 33065

Model Name: SERIES "MCKINLEY" ALUMINUM OUTSWING ENTRANCE DOOR

Maximum Load: +80 PSF, -115.2 PSF (Non-Impact)

Installation Drawings # W17-04

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ___ Yes __X__ No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Fenestration Testing Lab Blackwater Testing	04/28/2005 04/22/2019	FTL-4502 BT-ALD-18-002	Edmundo Largaespada, P.E. Constantin Bortes, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Lab Blackwater Testing	11/09/2004 02/03/2005 04/28/2005 09/26/2016 04/22/2019	FTL-4366 FTL-4404 FTL-4502 BT-ALD-16-005 BT-ALD-18-002	Edmundo Largaespada, P.E. Constantin Bortes, P.E.
AAMA 1304	Forced Entry	Fenestration Testing Lab Blackwater Testing	11/09/2004 02/03/2005 04/28/2005 09/26/2016 04/22/2019	FTL-4366 FTL-4404 FTL-4502 BT-ALD-16-005 BT-ALD-18-002	Edmundo Largaespada, P.E. Constantin Bortes, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ LICENSE No. 81223 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 8/10/2026