

STRUCTURAL SOLUTIONS, P.A.*

Structural Engineering ■ Investigations ■ Consulting

GARAGE DOOR EVALUATION REPORT

Garage Door No.:	IRC-5316-140-24-T		Test Date:	3/26/2015		Project No.:	15-034			
Design Pressures:	+29.3 psf, -33.3 psf		Report Date:	10/26/2020		Model #	500			
Test Pressures:	+44 psf, -50 psf		Test Location:	Entrematic, Winston-Salem, NC						
ASCE 7-16 Criteria:	Up to 5 Feet of Door Width in Zone 5; Any Roof Slope; Enclosed Building									
	Exp. B, 30' MRH		Exp. C, 15' MRH		Exp. C, 25' MRH		Exp. D, 15' MRH		Exp. D, 25' MRH	
	180 mph		164 mph		156 mph		149 mph		143 mph	

Reference Test Report and Drawing:

- Structural Solutions, P.A.* Garage Door Static Pressure Test Report for IRC-5316-140-24-T dated 10/26/2020
- Entrematic Drawing number IRC-5316-140-24-T dated 6/24/2015

Description of Test Specimen:

16'-0"x8'-0" Model 500, 24 ga steel garage door as shown in drawing IRC-5316-140-24-T.

Test Standards and Report Conclusion:

The above referenced Test Report states the following:

- The tests were conducted in accordance with ASTM E330-14 and DASMA 108-05.
- The test was witnessed and certified by Thomas L. Shelmerdine, PE (FL PE# 48579)
- The test facility at Entrematic is accredited by the American Association for Laboratory Accreditation, Certificate #2595.01.


Summary:

The 16'-0"x8'-0" Model 500 as described on drawing IRC-5316-140-24-T meets or exceeds the testing criteria as described above. By comparison to the construction of the 16'-0"x8'-0" Model 500, the following doors also meet or exceed the above testing criteria, when constructed in accordance with drawing IRC-5316-140-24-T:

- Classica 1000 doors (which is an alternate name for the Model 500)
- Classica 2000 doors (which is the Model 500 with drop-in insulation)
- Model 500, Classica 1000 and Classica 2000 doors with widths up to 16'-0" and heights up to 14'-0"
- 4 short panel windows (1/8" x 39" x 21-5/8" tempered glass minimum - meets ASTM E1300-04) may be installed in 1 section

To the best of my knowledge, the above garage door conforms to the requirements of the Florida Building Code 7th Edition (2020).

Submitted By:



STRUCTURAL SOLUTIONS, P.A.* (*Florida: dba Structural Solutions of North Carolina, Inc., Firm #29412)

Thomas L. Shelmerdine, PE (NC PE #14654; Florida PE #0048579)

5921-G West Friendly Avenue ■ Greensboro, North Carolina 27410 ■ (336) 856-2686 ■ www.sspa.biz ■ NC Firm #C-1096