



PRODUCT APPROVAL EVALUATION REPORT

<u>Product Manufacturer:</u> Global Performance Window Inc. d.b.a. Epsilon USA 2115 SW 2 ND Street Pompano Beach, FL 33069	<u>Product Name/Model & Description:</u> Series EUSA WW-40 Window Wall System - SMI Aluminum window wall system w/ insulated laminated glass— small missile impact
---	---

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 7th Edition Florida Building Code (2020), inclusive of all Supplements effective as of this report date.


Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

Product Description: Product Approval #AD15-46 prepared by MCY Engineering, signed and sealed by Yiping Wang P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
 - o Maximum allowable wind loads at the related maximum allowable size(s).
 - o Other load limitations applicable to the product, if any.
 - o Overall dimensions and material/grade of main product components, accessories, etc.
 - o Illustrated diagrams of the attachment of the product to the structure.
 - o Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.

Digitally signed by Yiping Wang
Location: 12781 Miramar Parkway #301, Miramar, FL
Reason: I am the author of this document
Contact Info:
mcy@mcyengineering.com
(305)-588-5224
Date: 2021.04.30 16:10:29+08'00'





Test Reports:

Mandatory Tests (Tested in accordance with AAMA 501)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Fenestration Testing Lab (FTL) – Medley, FL	<i>FTL-8236, signed and sealed by Idalmis Ortega, P.E.</i>	5/14/15	TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E331 (static pressure water resistance) ASTM E283 (air infiltration)
Excel Polymers, LLC. Burton, OH	61787	7/25/07	ASTM C 864 (EPDM rubber, seal gaskets, setting blocks, and spacers, 60 duro)
Excel Polymers, LLC. Burton, OH	74326	4/26/11	ASTM C 864 (EPDM rubber, seal gaskets, setting blocks, and spacers, 70 duro)
Blackwater Testing, Inc. (BT)-West Palm Beach, FL	<i>BT-EPU-16-003, signed and sealed by Constantin Bortes, P.E.</i>	6/6/16	TAS 201 (small missile impact) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E283 (air infiltration) ASTM E331 (static pressure water resistance)
Fenestration Testing Lab (FTL) – Medley, FL	<i>FTL-12553, signed and sealed by Idalmis Ortega, P.E.</i>	04/14/2021	TAS 201 (small missile impact) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)

Engineering Analysis: The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County.