

L. Roberto Lomas P.E.

1432 Woodford, Rd.
Lewisville, NC 27023
434 – 688 – 0609
rlomas@rlomaspe.com

Engineering Evaluation Report

Report No.: 514438

Manufacturer: **MI Windows and Doors, LLC.**
650 West Market Street
Gratz, PA 17030-0370

Product Line: Series 910 PVC Reinforced Finless Sliding Glass Door – 96" X 96" Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03434, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: E4673.01-109-47 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing, Inc. York, PA
AAMA/WDMA/CSA 101/I.S.2/A440-08
Design pressure: ± 20.05 psf
Water penetration resistance 5.43psf
3. Anchor calculations, report number 514438-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 20.0 psf
- Unit size: 96" x 96"
- Approved configurations: XO, OX
- Units must be glazed per ASTM E1300-04/09 with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03434.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

