

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 17893

Date: 09/22/2026

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC

Manufacturer Address: 3550 NW 49 STREET, MIAMI, FL 33142

Model Name: SERIES ES-6500 ULTRA 12 FT. ALUMINUM SLIDING GLASS DOOR W/ REINFORCEMENTS

Maximum Load: +120 PSF, -125 PSF (Large Missile Impact)

Installation Drawings # 18-45F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc	2/4/2014	FTL-7651	Idalmis Ortega, PE
			8/6/2012	FTL-6990	Marlin D. Brinson, PE
			4/5/2013	FTL-7130	Marlin D. Brinson, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Fenestration Testing Laboratory, Inc	2/4/2014	FTL-7651	Idalmis Ortega, PE
			8/6/2012	FTL-6990	Marlin D. Brinson, PE
			4/5/2013	FTL-7130	Marlin D. Brinson, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc	2/4/2014	FTL-7651	Idalmis Ortega, PE
			8/6/2012	FTL-6990	Marlin D. Brinson, PE
			4/5/2013	FTL-7130	Marlin D. Brinson, PE
ASTM F842	Forced Entry Test	Fenestration Testing Laboratory, Inc	2/4/2014	FTL-7651	Idalmis Ortega, PE
			8/6/2012	FTL-6990	Marlin D. Brinson, PE
			4/5/2013	FTL-7130	Marlin D. Brinson, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

Test	Description	Test Location	Test Report Date	Test Report#	Test Sealed By
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Fenestration Testing Laboratory, Inc	2/4/2014	FTL-7651	Idalmis Ortega, PE
			8/6/2012	FTL-6990	Marlin D. Brinson, PE
			4/5/2013	FTL-7130	Marlin D. Brinson, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.


Evaluation Report Engineer:

Jalal Farooq

Al-Farooq Corporation

PE # 81223

EB # 3538



Sealed: 9/22/2026