



AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 17896

Date: 08/19/2026

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC.

Manufacturer Address: 3550 N.W. 49 STREET – MIAMI, FL. 33142

Model Name: SERIES ES-7525 ALUMINUM CURTAINWALL SYSTEM

Maximum Load: +113 PSF, -120 PSF (Small Missile Impact)

Installation Drawings # W15-39

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used ☒ Yes ☐ No					
Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc.	06/05/2012 11/19/2011 08/05/2011	FTL-6742 FTL-6602 FTL-6193	Marlin D. Brinson. P.E.
		Blackwater Testing, Inc	02/25/2015 04/03/2019	BT-GMP-15-002 BT-GMP-18-002	Yamil Gerardo Kuri. P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Fenestration Testing Laboratory, Inc.	06/05/2012 05/11/2012 11/19/2011 08/05/2011	FTL-6742 FTL-6712 FTL-6602 FTL-6193	Marlin D. Brinson. P.E.
		Blackwater Testing, Inc	02/25/2015 04/03/2019	BT-GMP-15-002 BT-GMP-18-002	Yamil Gerardo Kuri. P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc.	06/05/2012 05/11/2012 11/19/2011 08/05/2011	FTL-6742 FTL-6712 FTL-6602 FTL-6193	Marlin D. Brinson. P.E.
		Blackwater Testing, Inc	02/25/2015 10/28/2015 05/18/2016 06/14/2016 01/31/2017 03/15/2017 04/03/2019	BT-GMP-15-002 BT-GMP-15-016 BT-ESW-16-001 BT-GMP-16-009 BT-ESW-16-012 BT-ESW-16-012A BT-GMP-18-002	Yamil Gerardo Kuri. P.E. Constantin Bortes. P.E.
ASTM F588	Forced Entry	Blackwater Technical Services	05/29/2020	BT-ESW-20-010	Michael D. Caldwell, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.3 TAS 201 & 203 ASTM E1886 ANSI Z97.1	Small Missile Impact & Cyclic	Fenestration Testing Laboratory, Inc. Blackwater Testing, Inc	11/19/2011 08/05/2011 02/25/2015 04/03/2019	FTL-6602 FTL-6193 BT-GMP-15-002 BT-GMP-18-002	Marlin D. Brinson. P.E. Yamil Gerardo Kuri. P.E. Constantin Bortes. P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.					
Evaluation Report Engineer: Jalal Farooq Al-Farooq Corporation			 Sealed: 8/19/2026		
PE # 81223 EB # 3538					