

L. Roberto Lomas P.E.

1432 Woodford Rd.

Danville, VA 24541

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 511924A

Manufacturer: MI Windows
650 West Market Street
Gratz, PA 17030

Product Line: 9660 Awning Window

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01315, Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: E3405.01-109-47 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440-08
Design pressure: +40.10/-35.09psf
Water penetration resistance 12.11psf
3. Report No.: E3406.01-109-47 signed and sealed by Michael D. Stremmel P.E.
Architectural Testing Laboratories, York, PA
AAMA/WDMA/CSA 101/I.S.2/A440-08
Design pressure: +40.10/-35.09psf
Water penetration resistance 12.11psf
4. Anchor calculations, report number 511924-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ± 35 psf
- Maximum unit size: 60" x 36"
- Units must be glazed per ASTM E1300-04.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation: Units must be installed in accordance with approval document, 08-01315, Revision A.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

