MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 Miramar Parkway, Suite 301
Miramar, FL. 33027
Mobile: (305) 588-5224
Office: (305) 271-0117

PRODUCT APPROVAL EVALUATION REPORT

Product Manufacturer:	*Product Name/Model & Description:*
C.T. Windows, LLC. *9195 Boggy Creek Rd. #1* *Orlando, FL 32824*	***Superior Series 400 Aluminum Casement Window – N.I.*** *Non-Impact Aluminum Casement Window*

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: **8th Edition Florida Building Code (2023)**, inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

Product Description: Product Approval **Drawing #AD11-15**, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **outside of the HVHZ** (High-Velocity Hurricane Zone)
- Impact Resistance: **Non-Impact**
- Refer to Product Approval Drawing noted above for:
  - Maximum allowable wind loads at the related maximum allowable size(s).
  - Other load limitations applicable to the product, if any.
  - Overall dimensions and material/grade of main product components, accessories, etc.
  - Illustrated diagrams of the attachment of the product to the structure.
  - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.

YIPING WANG
LICENSE
No 55983
STATE OF FLORIDA
PROFESSIONAL ENGINEER

November 16th, 2023

MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 Miramar Parkway, Suite 301
Miramar, FL. 33027
Mobile: (305) 588-5224
Office: (305) 271-0117

Test Reports:

Mandatory Tests (Tested in accordance with AAMA 501)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Fenestration Testing Laboratory, Inc. (FTL) – Medley, FL	*FTL-6576*	7/22/11	ASTM E283 (air infiltration) ASTM E330 (uniform static air pressure) ASTM E331 (water infiltration) ASTM E547 (water infiltration) TAS 202 (uniform static test) ASTM F588 (forced entry test)
Fenestration Testing Laboratory, Inc. (FTL) – Medley, FL	*FTL-6457*	3/10/11	ASTM E283 (air infiltration) ASTM E330 (uniform static air pressure) ASTM E331 (water infiltration) ASTM E547 (water infiltration) TAS 202 (uniform static test) ASTM F588 (forced entry test)
Fenestration Testing Laboratory, Inc. (FTL) – Medley, FL	*FTL-6152*	2/10/10	ASTM E283 (air infiltration) ASTM E330 (uniform static air pressure) ASTM E331 (water infiltration) ASTM E547 (water infiltration) TAS 202 (uniform static test) ASTM F588 (forced entry test)

Engineering Analysis: The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County, or ASTM TIR A9-91.
- No increase in allowable stress has been used in the evaluation of this product.

YIPING WANG
LICENSE
No 55983
STATE OF FLORIDA
PROFESSIONAL ENGINEER

November 16th, 2023