

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 18363

Date: 02/13/2018

Detailed Product Description :

Manufacturer: US ALUMINUM INC. – DIVISION OF CR LAURENCE CO.

Manufacturer Address: 7500 NW 69TH AVENUE MIAMI, FL 33166

Model Name: SERIES "DHS-500" ALUMINUM WINDOW WALL / STOREFRONT SYSTEM

Maximum Frame Width: 60"

Maximum Frame Height: 120"

Maximum Load: +130.0 PSF, -130.0 PSF (Small Missile Impact)

Installation Drawings # W15-53

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
The above maximum parameters do not occur simultaneously. See installation drawings for combination of span vs loads and anchor type.					
Comparative analysis used <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory	07/09/2008 12/19/2006 09/15/2004 08/31/2004 06/28/2004	FTL-5662 FTL-4989 FTL-4320 FTL-4306 FTL-4254	Carlos Rionda, P.E. Michael Wenzel, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E.
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Fenestration Testing Laboratory	07/09/2008 12/19/2006	FTL-5662 FTL-4989	Carlos Rionda, P.E. Michael Wenzel, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory	07/09/2008 12/19/2006 09/15/2004 08/31/2004 06/28/2004	FTL-5662 FTL-4989 FTL-4320 FTL-4306 FTL-4254	Carlos Rionda, P.E. Michael Wenzel, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E.

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)


TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.3 (TAS 201 & 203)	Small Missile Impact & Cyclic	Fenestration Testing Laboratory	07/09/2008 12/19/2006 09/15/2004 08/31/2004 06/28/2004	FTL-5662 FTL-4989 FTL-4320 FTL-4306 FTL-4254	Carlos Rionda, P.E. Michael Wenzel, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E. Edmundo Largaespada, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

Evaluation Report Engineer:

Javad Ahmad
Al-Farooq Corporation

PE # 70592
EB # 3538



Sealed: 2/14/2018