



MCY ENGINEERING, INC.
GLAZING CONSULTANT

12781 Miramar Pkwy. Ste. 301
Miramar, FL. 33027
P: 305 271-0117
F: 305 279-6818

PRODUCT APPROVAL EVALUATION REPORT

<u>Product Manufacturer:</u> Continental Glass Systems, Inc. 325 West 74 th Place, Hialeah, FL. 33014	<u>Product Name/Model & Description:</u> Series 7200 Casement Window System – SMI Casement Window - Small Missile Impact
--	---

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 7th Edition Florida Building Code (2020), inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

Product Description: Product Approval Drawing #AD15-72, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **Inside and Outside of the HVHZ** (High-Velocity Hurricane Zone)
- Impact Resistance: **Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
 - Maximum allowable wind loads at the related maximum allowable size(s).
 - Other load limitations applicable to the product, if any.
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to the structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



Test Reports:

Mandatory Tests (Tested in accordance with AAMA 501)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Blackwater Testing, Inc. - West Palm Beach, FL	<i>BT-CON-15-008, signed and sealed by Yamil G. Kuri, P.E.</i>	8/24/15	ASTM E283 (air infiltration) ASTM E331 (water resistance test) AAMA 1304 (forced entry test) TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Hurricane Engineering & Testing, Inc.	<i>HETI-13-4068, signed and sealed by Rafael DrozSeda, P.E.</i>	10/29/13	ASTM E283 (air infiltration) ASTM E331 (water resistance test) ASTM E330 (structural performance) ASTM F588 (AAMA 1304 (forced entry test) TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Hurricane Engineering & Testing, Inc.	<i>HETI-13-4069, signed and sealed by Rafael DrozSeda, P.E.</i>	10/29/13	ASTM E1886 (Small missile impact) ASTM E1996 (cyclic wind pressure load) TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Hurricane Engineering & Testing, Inc.	<i>HETI-13-4071, signed and sealed by Rafael DrozSeda, P.E.</i>	10/24/13	ATM E283 (air infiltration) ASTM E330 (uniform load test) ASTM E331 (water resistance test) TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)
Hurricane Engineering & Testing, Inc.	<i>HETI-13-4072 signed and sealed by Rafael DrozSeda, P.E.</i>	10/24/13	ASTM E1886 (Small missile impact) ASTM E1996 (cyclic wind pressure load) TAS 201 (small missile impact test) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading)

Engineering Analysis:

 The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County.



October 12th, 2020