AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 18410

Date: 09/02/2026

Detailed Product Description:

Manufacturer: E.S. WINDOWS, LLC

Manufacturer Address: 3550 NW 49TH STREET MIAMI, FL 33142

Model Name: ES-WW1032 (SLANTED) ALUMINUM WINDOW WALL SYSTEM

Maximum Load: +168 PSF, -168 PSF (Small Missile Impact)

Installation Drawings # 25-51F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used Yes _X_ No __

Mandatory Tests (Tested in accordance with AAMA 501/101/I.S.2/NAFS/TAS 202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	IFET, Inc.	4/11/2025	IFET-24-0089	Arshad Viqar, PE
ASTM E331 or ASTM 547 & TAS 202	Water Penetration	IFET, Inc.	4/11/2025	IFET-24-0089	Arshad Viqar, PE
ASTM E330 & TAS 202	Uniform Static Air Pressure	IFET, Inc.	4/11/2025	IFET-24-0089	Arshad Viqar, PE

Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.3 (TAS 201 & 203) ANSI Z97.1	Small Missile Impact & Cyclic	IFET, Inc.	4/11/2025	IFET-24-0089	Arshad Viqar, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq PE # 81223
Al-Farooq Corporation EB # 3538

JALAL FAROOQ LICENSE No. 81223 STATE OF FLORIDA PROFESSIONAL ENGINEER

Sealed: 9/2/2026