

**L. Roberto Lomas P.E.**

208 7<sup>th</sup> Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 513575B**

**Manufacturer:** Sky-Frame, Inc.  
Langfeldstrasse 111  
Frauenfeld, Switzerland CH-8500

**Product Line:** Series SF2 – CW50 Aluminum SGD, Non-Impact

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02788 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report C6429.02-250-44-R3 signed and sealed by Justin P McDonald, P.E.  
Architectural Testing Inc., Chelmsford, MA  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: ±50.13psf  
Water penetration resistance 8.15psf
3. Anchor calculations, report number 513575-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: ±50.0psf
- Panel size: 68 ¾" x 97 ¾"
- Approved configurations: OX, XO.
- Units must be glazed per ASTM E 1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Aluminum 6060-T64.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02788, Revision B.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

