

**PRODUCT EVALUATION REPORT**

- Florida Building Code - 8th Edition (2023) -
Per Rule 61G20-3 / Method 1 - (d)

FL #: **18607.4**DATE: **02/17/2026****Product Description**

Manufacturer: SKY-FRAME AG
Address: Langfeldstrasse 111. Frauenfeld, Switzerland CH-8500
Model Name: Series SF-3 HORIZONTAL SLIDING DOOR (L.M.I./S.M.I.)
Maximum Load: +75.0 PSF / -75.0 PSF (Large & Small Missile Impact)
Drawing No.: JA-1459-25, signed and sealed by Javad Ahmad, PE. - FL License No. 70592

This product COMPLIES with the 2023 Florida Building Code - 8th Edition (2023 FBC) for use in the High-Velocity Hurricane Zone (HVHZ) per TAS 201/202/203.

For maximum sizes and anchor type refer to installation drawings.

Comparative Analysis used: ☒ YES ☐ NO

Mandatory Tests (Tested in accordance with AAMA 501 / 101 / I.S.2 / NAFS / TAS 202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 202-94 TAS 202-94 TAS 202-94 ASTM F842	Uniform Static Test Air Infiltration Leakage Water Penetration Forced Entry Resistance	Intertek, Fresno, CA.	01/24/2019	11185.01-301-44 R0	Tyler Westerling, P.E. FL PE# 72012
ASTM E283/E283M-19 TAS 202-94 ASTM E331-00(2016) ASTM F842	Air Infiltration Leakage Uniform Static Test Water Penetration Forced Entry Resistance	IFET, Inc. - FL 33126	12/10/2025	TR-IFET-25-0062-A	Arshad Viqar, P.E. FL PE# 38863

Supplemental Tests (Tested in accordance with TAS 201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST REPORT SEALED BY
TAS 201-94 TAS 203-94	Impact Test (Large Missile Impact, Level D, Wind Zone 4) Cyclic Wind Pressure Load	Intertek, Fresno, CA.	1/24/2019	11185.01-301-44 R0	Tyler Westerling, P.E. FL PE# 72012
TAS 201-94 TAS 203-94	Impact Test (Large Missile Impact) Cyclic Wind Pressure Load	IFET, Inc. - FL 33126	12/10/2025	TR-IFET-25-0062-A	Arshad Viqar, P.E. FL PE# 38863


Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code - 8th Edition (2023 FBC).

Evaluation Report Engineer:**Javad Ahmad, PE**

FL P.E.# 70592

EB C.A.N. # 34254

JAVAD AHMAD PE, Inc.



Sealed: 02/17/2026