L. Roberto Lomas P.E.
233 W. Main St
Danville, VA 24541
434-688-0609
rllomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513652

Manufacturer: Comfort View Products LLC
320 Coweta Industrial Park
Newnan, GA 30265

Product Line: Series 920 Vinyl Horizontal Sliding Window with Sill Extender 72” x 48” Non-Impact

Compliance:
The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:
1. Approval document: drawing number 08-02849, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No. E8068.02-501-471 signed by Lynn George.
   Architectural Testing, Inc. Springdale, PA
   AAMA/WDMA/CSA 101/I.S.2/A440-11
   Design pressure: +50.13/-55.14psf
   Water penetration resistance 7.52psf
3. Anchor calculations, report number 513652-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:
- Maximum design pressure: +50.0/-55.0psf
- Maximum unit size: 72” x 48”
- Units must be glazed per ASTM E1300-04.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation: Units must be installed in accordance with manufacturer’s installation instructions and approval document 08-02849.

Certification of Independence: Please note that I don’t have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don’t have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

Luis R. Lomas, P.E.
FL No.: 62514
01/28/2016