



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E. Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

Tubelite, Inc.

**E/T/TU 24650 Series Storefront System
(NON-HVHZ)(NON-IMPACT)**

for

Florida Product Approval

FL# FL20393

Report No. 7201

Current Florida Building Code

Method: 1 – D (Engineering Evaluation)
Category: Panel Walls
Sub – Category: Storefronts

Product: E/T/TU 24650 Series Storefront System
Material: Aluminum 6063-T5
Product Dimensions: See Installation Instructions, TLI009

Prepared for:

Tubelite, Inc.

**3056 Walker Ridge Drive N.W.
Walker, Michigan 49544**

Prepared by:

Hermes F. Norero, P.E.


Florida Professional Engineer # 73778

Date: 10/05/2020

Contents:

Evaluation Report

Pages 1 – 4



Hermes F. Norero, P.E.
Florida P.E. No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: **FL20393**
Date: 10/05/2020
Report No: 7201

Manufacturer: Tubelite, Inc.

Product Category: Panel Walls

Product Sub-Category: Storefronts

Compliance Method: State Product Approval Method (1)(d)

Product Name: E/T/TU 24650 Series Storefront System
(Non-HVHZ)(Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Tubelite, Inc.** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **TL1009**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and **does** require an impact resistant covering.
4. Site conditions that deviate from the details of Installation Instructions **TL1009** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **TL1009** for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL20393
Date: 10/05/2020
Report No: 7201

Quality Assurance: The manufacturer has demonstrated compliance of products in accordance with the Current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Architectural Testing, Inc., an Intertek Company** (FBC Organization #: QUA1844).

Performance Standards: The product described herein has been evaluated per:

- ASTM E 283-04(12)
- ASTM E 331-00(09)
- ASTM E 330-14
- AAMA 501-15

Referenced Data:

1. Product Testing performed by **Intertek / Architectural Testing, Inc., West Palm Beach, FL** (FBC Organization # TST1527)

Report:

J2424.02-450-32

J2424.03-450-32

F2003.03-450-32

Dated:

08/15/19

08/15/19

02/10/16

2. Quality Assurance
Architectural Testing, Inc., an Intertek Company
(FBC Organization #: QUA1844)

Installation:

Refer to Installation Instructions, **TLI009**, for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to installation instructions, **TLI009**, for design pressures dependent on size options.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL20393

Date: 10/05/2020

Report No: 7201

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. **TubeLite, Inc.** has tested their products to the following test standard edition(s):

- 1) ASTM E 331-00(16)
- 2) AAMA 501-17/07/09

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) ASTM E 331-00(09)
- 2) AAMA 501-15

After review of the above mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results. All referenced standards have been found to be equivalent.