RICE
ENGINEERING
Rice Engineering, Inc.
105 School Creek Trail | Luxemburg, WI 54217
(P) 920.617.1042 | (F) 920.617.1048

Engineering Evaluation Report

Manufacturer:
Winco Window Co.
6200 Maple Ave.
St. Louis, MO 63130

Product Line:
3250 Project-Out Awning – Non-Impact

Product Description:
Architectural Aluminum Window. Frame made from 6063-T6 Aluminum. Insulated Glass, outboard to inboard, consisting of 1/4" AN – 1/2" Air – 1/4" AN.

Compliance:
The above product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.006. The product Herein complies with the Florida Building Code 7th Edition (2020).

Documentation:
1. Report No: 14036I
   Mid America Testing Lab Inc.
   Catawissa, MO
2. AAMA CPD# 12866
3. Anchor Calculations prepared, signed, and sealed by Wayne Helmila, PE
4. Drawings titled 3250 PO Non-Impact prepared, signed, and sealed by Wayne Helmila, PE

Codes & Limitations:

1.	ASTM E330-14	+\- 80 psf
2.	ASTM E1300-12	
3.	AAMA/WDMA/CSA 101/I.S.2/A440-08	CW-PG80-AP
4.	Max. window size	60" x 36"
5.	Max. design pressure	+\- 80 psf

6. Product is not approved for large missile impact protection and requires impact protection in wind-borne debris regions.
7. Units must be installed in accordance with manufacturer instructions.

Certificate of Independence:
I certify that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Additionally, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

WAYNE K. HELMILA
LICENSE
No. 59092
STATE OF FLORIDA
PROFESSIONAL ENGINEER

12/13/2020
COA: 9090

RICE
ENGINEERING
105 School Creek Trail
Luxemburg, WI 54217
Phone: (920) 617-1042
Fax: (920) 617-1100
www.rice-inc.com

Florida Firm No: F-01000005061
Certificate of Authorization: #9090
Wayne K. Helmila
Registration No: 59092