

Product Evaluation Report
Report No.: FL-20461.16
Date: July 19, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Therma-Tru Corporation 118 Industrial Dr Edgerton, OH 43517 Phone 419-298-1740	Fiber-Classic and Smooth-Star Composite Edge Glazed Fiberglass Double Door w/ or w/out Sidelites Inswing / Outswing "Non-Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Therma-Tru Corporations, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection, this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
5. Site conditions that deviate from the details of drawing FL-20461.16 require further engineering analysis by a licensed engineer or registered architect.
6. Fiber-Classic & Smooth-Star Door and Sidelite panels require the use of "J" part numbers and must be stained or painted within six months of installation
7. See drawing FL-20461.16 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|--|---|---|--|
| <ol style="list-style-type: none"> 1. Test Report No.
TEL 01460145
ETC 01-741-10593.0
TEL 01461573
TEL 01461939 2. Drawing No.
No. FL-20461.16 3. Calculations
ASTM E 1300 Glass Load
Anchoring 4. Quality Assurance
Certificate of Participation issued by National Accreditation & Management Institute, certifying that Therma-Tru Corporations is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | <ol style="list-style-type: none"> 1. Test Standard
ASTM E330-02
TAS 202-94
ASTM E330-02 & ASTM E331-00
ASTM E330-02 & ASTM E331-00 2. Prepared by
RW Building Consultants, Inc. (#9813) 3. Prepared by
RW Building Consultants, Inc. (#9813)
RW Building Consultants, Inc. (#9813) | <ol style="list-style-type: none"> 1. Testing Laboratory
Testing Evaluation Lab., Inc.
ETC Laboratories
Testing Evaluation Lab., Inc.
Testing Evaluation Lab., Inc. | <ol style="list-style-type: none"> 1. Signed by
V.K. Wright
Mark D. Passero, P.E.
V.K. Wright
V.K. Wright 2. Signed & Sealed by
Lyndon F. Schmidt, P.E. 3. Signed & Sealed by

Lyndon F. Schmidt, P.E. |
|--|---|---|--|

Digitally signed by Lyndon F Schmidt
Date: 2023.07.25 16:46:10 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 7-25-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA