



PRODUCT APPROVAL EVALUATION REPORT

<u>Product Manufacturer:</u> NR Architectural Products, Inc. 4348 Westroads Dr. Riviera Beach, FL 33407	<u>Product Name/Model & Description:</u> 7000 Series Lift and Sliding Glass Door-L.M.I. 7000 Series Lift and Sliding Glass Door-S.M.I.
---	--

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 8th Edition Florida Building Code (2023), inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1) (d) – Evaluation Report from a licensed Professional Engineer


Product Description: Product Approval Drawing #AD24-33A, #AD24-33B prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside of the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Large and Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Other load limitations applicable to the product, if any.
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to the structure
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



February 10th, 2026



Test Reports:


Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Intertek.-West Palm Beach, FL.	s8897.01-450-18-r0 signed and sealed by TANYA A. DOLBY P.E. FL #93536	12/31/2025	TAS 201 (large missile impact) TAS 203 (cyclic wind pressure loading)
Intertek.-West Palm Beach, FL.	s8897.02-450-18-r0 signed and sealed by TANYA A. DOLBY P.E. FL #93536	12/31/2025	TAS 201 (small missile impact) TAS 202 (uniform static load) TAS 202 (air leakage) TAS 202 (water leakage) TAS 203 (cyclic wind pressure loading) ASTM F842 (forced entry)

Engineering Analysis:

The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County.



February 10th, 2026