

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 20701

Date: 8/8/17

Detailed Product Description:

Manufacturer: ENVIRALUM INDUSTRIES, INC

Manufacturer Address: 5100 NW 72ND AVENUE, BLDG C. MIAMI, FL 33166

Model Name: SERIES ENV-350 ALUMINUM INSWING ENTRANCE DOOR (L.M.I)

Maximum Frame Width: 47"

Maximum Frame Height: 118-1/4"

Maximum Load: +93 PSF, -93 PSF (Large Missile Impact)

Installation Drawings # W17-36

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

Comparative analysis used Yes No

Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS-02/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
ASTM E283	Air Infiltration Leakage	Blackwater Testing, Inc	04/06/2017	BT-ENI-16-004	Constantin Bortes, P. E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Testing, Inc	04/06/2017	BT-ENI-16-004	Constantin Bortes, P. E.
AAMA 1304	Forced Entry Test	Blackwater Testing, Inc	04/06/2017	BT-ENI-16-004	Constantin Bortes, P. E.


Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
FBC 1626.2 (TAS 201 & 203) ASTM E1886/E1996	Large Missile Impact & Cyclic	Blackwater Testing, Inc	04/06/2017	BT-ENI-16-004	Constantin Bortes, P. E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2017 Florida Building Code.

Evaluation Report Engineer:

Javad Ahmad PE # 70592
Al-Farooq Corporation EB # 3538



Sealed: 08/08/2017