

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513250D

Manufacturer: Reilly Window & Door
901 Burman Blvd., Bldg. 701
Calverton, NY 11933

Product Line: Series RWD Wood French Door In-Swing

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02489 Revision D, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: 12-0162-3A Rev. 1 & 12-0162-4F Rev. 1 signed and sealed by Alexis Spyrou P.E.
MT Group Materials Testing Lab, Inc., Farmington, New York
TAS 201 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 Uniform Static Air Pressure, ± 65.0 psf design pressure, 13.5psf water penetration.
TAS 203 Cyclic Pressure loading ± 75.0 psf design pressure
3. Test report No.: 96977 signed and sealed by Charles L. Anderson P.E.
Intertek MT Group Inc., Farmingdale, NY
TAS 201 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
TAS 203 Cyclic Pressure loading ± 55.0 psf design pressure
4. Anchor calculations, report number 513250-1C & -2A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: Refer to installation drawing.
- Unit size: 82 5/16" x 96 1/2"
- Panel size: 40 1/8" x 94 3/16"
- Approved configurations: XX, X.
- Units must be glazed per ASTM E1300, see installation instructions for glass details.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be wood, mahogany.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02489 Revision D.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

