

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515278B

Manufacturer: Reilly Window and Door
901 Burman Blvd., Bldg. 701
Calverton, NY 11933

Product Line: Series RWD Wood French Door Out-Swing Impact

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03987 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: MT 12-0162-3A, 3C and 3F signed and sealed by Alexis Spyrou P.E.
Material Testing Lab, Inc. York, PA
TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 75.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 65.0 psf design pressure, 13.5psf water penetration.
3. Report No.: G4946.01-525-44 signed by Craig Ginsberg.
Architectural Testing, Inc., Calverton, NY
ASTM E330
 ± 60.0 psf design pressure
ASTM E1886/E1996
Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Load Test, ± 60.0 psf design pressure
4. Test report No.: 96977 signed and sealed by Charles L. Anderson P.E.
Intertek MT Group Inc., Farmingdale, NY
TAS 201/ TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 55.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
5. Anchor calculations with comparative analyses, report number 515278-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: Refer to approval drawing.
- Unit size: Refer to approval drawing
- Approved configuration: XX, X.
- Units must be glazed per ASTM E1300, see installation instructions for glass details.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be wood, mahogany.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03987 revision A.

When the product specified herein is installed within 3000 ft. of a saltwater coastline, all anchors and clips must comply with saltwater environment corrosion resistance requirements of FBC Chapter 17.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

