



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: FL-21142.18

Date: August 18, 2023

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Therma Tru Corporation 118 Industrial Drive Edgerton, OH 43517 Phone 419.298.1740	Fiber-Classic and Smooth-Star Wood Edge Opaque Fiberglass Single Door w/ Sidelite(s) Inswing/Outswing "Non-Impact"

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. for Therma Tru Corporation based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements including the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in the "HVHZ" this product must be protected with an impact resistant covering complying with FBC Section 1626.
- When used in areas outside of the "HVHZ" requiring wind borne debris protection, this product is required to be protected with an impact resistant covering complies with FBC Section 1609.1.2 & R301.2.1.2 as follows: Wind Zones 1, 2 & 3: Glazed Sidelites only; Wind Zone 4: Entire System.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-21142.18 require further engineering analysis by a licensed engineer or registered architect.
- Outswing configurations using Coastal Sill (items #19) & Composite Sill (item #16) under active doors meet water infiltration requirements for "HVHZ". All other configurations do not meet the water infiltration requirements for the "HVHZ" and shall be installed only in non-habitable areas or at habitable locations protected by an overhang or canopy such that the angle between the edge of canopy or overhang to sill is less than 45 degrees.
- Fiber-Classic & Smooth-Star Sidelites panels require the use of "J" part numbers and must be stained or painted within six months of installation.
- See drawing FL-21142.18 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|--|--|---|
| 1. Test Report No.
ETC 01-741-10700.0
ETC 01-741-10702.0
ETC 01-741-11008.0
TEL 06-1031-02
NCTL 210-1940-1,2,3,4
TEL 01460146
ETC 01-741-10593.0
ETC 01-741-10703.0
ETC 01-741-11006.0
TEL 01460144 | Test Standard
TAS 202-94
TAS 202-94
TAS 202-94
TAS 202-94, TAS 201/203-94
TAS 202-94
TAS 202-94, TAS 201/203-94
TAS 202-94
TAS 202-94
TAS 202-94
TAS 202-94, TAS 201/203-94
TAS 202-94, TAS 201/203-94 | Testing Laboratory
ETC Laboratories
ETC Laboratories
ETC Laboratories
Testing Evaluation Labs
National Certified Testing
Testing Evaluation Labs
ETC Laboratories
ETC Laboratories
ETC Laboratories
Testing Evaluation Labs | Signed by
Wendell W. Haney, P.E.
Wendell W. Haney, P.E.
Joseph Doldan, P.E.
Wendell W. Haney, P.E.
Barry Portnoy, P.E.
Lyndon F. Schmidt, P.E.
Mark Passero, P.E.
Wendell W. Haney, P.E.
Joseph Doldan, P.E.
Lyndon F. Schmidt, P.E. |
| 2. Drawing No.
No. FL-21142.18 | Prepared by
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 3. Calculations
Anchoring
ASTM E1300 Glass Load | Prepared by
RW Building Consultants, Inc. (#9813)
Lyndon F. Schmidt, P.E. | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Therma Tru Corporation is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

Digitally signed by
Lyndon F Schmidt
Date: 2023.08.18
16:05:10 -04'00'

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 8-18-23.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA