L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 513811A

Manufacturer: US Aluminum Division of C.R. Laurence Co., Inc.

2503 E. Vernon Ave. Los Angeles, CA 90058

Product Line: Series D900 Thermally improved aluminum architectural terrace Door

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- Approval document: drawing number 08-02966, Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: A3326.02-801-18 signed and sealed by Shawn G. Collins, P.E.

Architectural Testing, Inc. Southlake, TX

TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4

TAS 202 -94 Uniform Static Air Pressure, ±65.0psf design pressure, 15.0psf water penetration.

TAS 203-94 Cyclic Pressure loading ±65.0psf design pressure

3. Anchor calculations, report number 513811-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


Maximum design pressure: ±65.0psf
Maximum frame size: ±65.0psf
36" x 117 ½"

• Approved Configurations: X

- Units must be glazed per ASTM E1300-04/09, see installation instructions for details.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be aluminum 6063-T5.

Installation: Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02966, Revision A.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 03/15/2017