

SWARTZ
CONSULTING ENGINEERS LLC

Project Number:	SCE 25-04011
Project Name:	Siteline (W-5500) Clad Wood ISW Door
Date:	11/6/2025
Page:	1 of 17

Product Evaluation Report: R2 Method 1D

Project Number: SCE 25-04011

Product Name: Siteline (W-5500) Clad Wood ISW Door

Product Dimensions: 35.625 x 119.5

Design Pressure: +50 psf / -55 psf

Impact: Wind Zone 3 - Level D Missile

Installation Instructions: D003486


Method: 1-D (Engineering Evaluation)

Category: Exterior Doors


Subcategory: Swinging Exterior Doors

Prepared for:

Jeld-Wen Windows & Doors
3737 Lakeport Blvd.
Klamath Falls, OR




Prepared by:
Swartz Consulting Engineers LLC


Micah Swartz, PE
Florida License No. PE 93573
Florida Registry No. 38420

11/06/25

This item has been digitally signed and sealed by Micah Swartz, P.E. on the date adjacent to the seal.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Scope:

This is a product evaluation report issued by Micah Swartz, P.E. (FL# 93573) for Jeld-Wen Windows & Doors based on Method 1D of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions D003486, signed and sealed by Micah Swartz, P.E. (FL# 93573) for specific use paramaters including size and design pressure limitations.

Reference Standards:

Current edition of the Florida Building Code, Building


ANSI/AWC NDS - National Design Specification (NDS) for Wood Construction

AISI S100 North American Specification for the Design of Cold-Formed Steel Structural Members

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners

ICC-ES Report ESR-2196 Hilti Self Drilling Screws to connect cold-formed steel

NOA 24-0102.06 Tapcon Concrete and Masonry Anchors with Advanced Threadform Technology



Limits of Use:

- (1) Product anchors shall be as listed and spaced on installation instructions. Anchors shall be embedded into the substrate the full embedment depth beyond stucco or wall cladding.
- (2) Site conditions that deviate from the details of drawing D003486 must be verified and designed by a licensed engineer or registered architect.

Certification of Independence:

In accordance with Rule 61G20-3 Florida Administrative Code, Swartz Consulting Engineers LLC hereby certifies the following:

- (1) Swartz Consulting Engineers LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- (2) Swartz Consulting Engineers LLC is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- (3) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- (4) Micah Swartz, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.



Design Summary:

The table below summarizes the product: Siteline (W-5500) Clad Wood ISW Door 35.625 x 119.5 and their corresponding performance levels as established by testing.

Table 1: Summary of Test Results

Series/Model	Test Report Number	Standards Tested	Size (W x H)	Performance
Siteline (W-5500) Clad Wood ISW Door 35.625 x 119.5	28937.01-201-12 (07/23/24)	AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E283-19 ASTM E330 -14(2021) ASTM E547-00(2016) AAMA 1304-18 ASTM 1886-19/1996-20	35.625 x 119.5	+50 psf / -55 psf

As Tested Design:

Screw Information:

Screw Size: 8 Screw Embed: 1.25 in Edge Distance: 3/4 in (minimum)
qty: 1 Spacing: 16 in O.C. (Thru Frame)


Wood Screw Lateral: 106 lbs Per ft. Capacity: 79 plf

Alternative Fasteners:

Screw Information:

Screw Size: 8 Screw Embed: 1.25 in Edge Distance: 3/4 in (minimum)
qty: 1 Spacing: 8 in O.C. (Nail Fin)
qty: 1 Spacing: 16 in O.C. (Thru Frame)

Wood Screw Withdrawal: 164 lbs Per ft. Capacity: 246 plf Unity: 0.32
Wood Screw Lateral: 106 lbs Per ft. Capacity: 79 plf Unity: 1.00



Design Summary Continued:

Nail Information:

Nail Size: 6d Nail Type: Common Edge Distance: 3/4 in (minimum)
qty: 1 Spacing: 8 in O.C. (Nail Fin)
qty: 2 Spacing: 16 in O.C. (Strap)

Nail Withdrawal:	55 lbs	Per ft. Capacity:	83 plf	Unity:	0.96
Nail Lateral:	113 lbs	Per ft. Capacity:	170 plf	Unity:	0.47

TEK Screw Information:


Screw Size: 10-16 qty: 1 Spacing: 16 in O.C. (Thru Frame)
qty: 1 Spacing: 16 in O.C. (Nail Fin)

TEK Withdrawal:	145 lbs	Per ft. Capacity:	109 plf	Unity:	0.73
TEK Lateral:	147 lbs	Per ft. Capacity:	110 plf	Unity:	0.72

Tapcon Information:

Tapcon Size: 3/16 Embedment: 1-1/4 in (minimum) Edge Distance: 2-1/2 in (minimum)
qty: 1 Spacing: 16 in O.C.

Tapcon Lateral (Concrete):	155 lbs	Per ft. Capacity:	116 plf	Unity:	0.68
Tapcon Lateral (CMU):	135 lbs	Per ft. Capacity:	101 plf	Unity:	0.78



Subject: As Tested - Wood Screw Lateral Design - Single Shear

Input:
Calculation:

Screw Information:

Screw Size: Root Diameter: in
Screw Embed: in

Main Member Type: G: F_{em}: psi thickness (t_m): in

Side Member Type: G: F_{es}: psi thickness (t_s): in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	0.131 in	Diameter
F _{yb} :	100 ksi	Dowel Bending Yield Strength
F _{em} :	3,350 psi	Main Member dowel bearing strength
F _{es} :	3,350 psi	Side Member dowel bearing strength
l _m :	1.25 in	Main Member dowel bearing length
l _s :	1.25 in	Side Member dowel bearing length
R _d :	2.2	Reduction term - Table 12.3.1B (NDS)
R _e :	1	= F _{em} /F _{es}
R _t :	1.0	= l _m /l _s
k ₁ :	0.414	See Table
k ₂ :	1.158	See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

Z_{I_m}: lbs $Z_{I_m} = \frac{D l_m F_{em}}{R_d}$ (EQ 12.3 - 1)


Z_{II}: lbs $Z_{II} = \frac{k_1 D l_s F_{es}}{R_d}$ (EQ 12.3 - 3)

Z_{III_m}: lbs $Z_{III_m} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d}$ (EQ 12.3 - 4)

Z_{IV}: lbs $Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}}$ (EQ 12.3 - 6)

Z_{MIN}: lbs

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{I_s} and Z_{III_s} are not applicable to the calculation.



Subject: As Tested - Wood Screw Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': \boxed{132} \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L:	0.25	in Maximum Shim Gap
D:	0.131	in Diameter
F_{yb} :	100	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb} \pi D^3}{16 \Omega L} \quad \text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$


$$Z_n/\Omega: \boxed{106} \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t:	20	GA
t:	0.036	in thickness of strap
D:	0.131	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: \boxed{140} \text{ lbs}$$



Subject: Wood Screw Withdrawal

Input:
Calculation:

Screw Information:

Screw Size: Root Diameter: in
Screw Embed: in

Main Member Type: G: F_{em}: psi

$$W' = W * C_D * C_M^2 * C_t - \text{As per table 11.3.1 NDS}$$

C_D: Load Duration Factor - Table 2.3.2 (NDS)


C_M: Wet Service Factor - Table 11.3.3 (NDS)

C_t: Temperature Factor - Table 11.3.4 (NDS)

W: lbs/in - Table 12.2B (NDS)

W: lbs

W': lbs



Subject: Wood Screw Lateral Design - Single Shear

Input:
Calculation:

Screw Information:

Screw Size: Root Diameter: in
Screw Embed: in

Main Member Type: G: F_{em} : psi thickness (t_m): in

Side Member Type: G: F_{es} : psi thickness (t_s): in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	0.131 in	Diameter
F_{yb} :	100 ksi	Dowel Bending Yield Strength
F_{em} :	3,350 psi	Main Member dowel bearing strength
F_{es} :	3,350 psi	Side Member dowel bearing strength
l_m :	1.25 in	Main Member dowel bearing length
l_s :	1.25 in	Side Member dowel bearing length
R_d :	2.2	Reduction term - Table 12.3.1B (NDS)
R_e :	1	$= F_{em}/F_{es}$
R_t :	1.0	$= l_m/l_s$
k_1 :	0.414	See Table
k_2 :	1.158	See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

$$Z_{Im}: \text{ lbs } \quad Z_{Im} = \frac{D l_m F_{em}}{R_d} \text{ (EQ 12.3 - 1)}$$


$$Z_{II}: \text{ lbs } \quad Z_{II} = \frac{k_1 D l_s F_{es}}{R_d} \text{ (EQ 12.3 - 3)}$$

$$Z_{III}: \text{ lbs } \quad Z_{III} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d} \text{ (EQ 12.3 - 4)}$$

$$Z_{IV}: \text{ lbs } \quad Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}} \text{ (EQ 12.3 - 6)}$$

$$Z_{MIN}: \text{ lbs }$$

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{Is} and Z_{IIIs} are not applicable to the calculation.



Subject: Wood Screw Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': 132 \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L:	0.25	in Maximum Shim Gap
D:	0.131	in Diameter
F_{yb} :	100	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb} \pi D^3}{16 \Omega L} \quad \text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$


$$Z_n/\Omega: 106 \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t:	20	GA
t:	0.036	in thickness of strap
D:	0.131	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: 140 \text{ lbs}$$



Subject: Nail Withdrawal

Input:

Calculation:

Nail Information:

Nail Size: 6d

Nail Length: 2 in

Nail Type: Common

Nail Diameter: 0.113 in

Nail Embedment: 1.94 in

Main Member Type: S-P-F

G: 0.42

F_{em}: 3,350 psi thickness (t_m): 1.5 in

Side Member Type: Alum

G: N/A

F_{es}: 13,750 psi thickness (t_s): 0.0625 in

$$W' = W * C_D * C_M^2 * C_t - \text{As per table 11.3.1 NDS}$$

C_D: 1.6 Load Duration Factor - Table 2.3.2 (NDS)

C_M: 1.0 Wet Service Factor - Table 11.3.3 (NDS)


C_t: 1.0 Temperature Factor - Table 11.3.4 (NDS)

W: 18 lbs/in

W: 35 lbs

$$W = 1380G^{5/2}D - \text{Carbon Steel Nails (EQ. 12.2 - 3, NDS)}$$

W': 55 lbs



Subject: Nail Lateral Design - Single Shear

Input:

Calculation:

Nail Information:

Nail Size: 6d

Nail Length: 2 in

Nail Type: Common

Nail Diameter: 0.113 in

Nail Embedment: 1.69 in

Main Member Type: S-P-F

G: 0.42

F_{em}: 3,350 psi thickness (t_m): 1.5 in

Side Member Type: Alum

G: N/A

F_{es}: 21,000 psi thickness (t_s): 0.0625 in

Lateral Design Factors - Table 12.3.1A (NDS)

D:	<u>0.113</u> in	Diameter
F _{yb} :	<u>100</u> ksi	Dowel Bending Yield Strength
F _{em} :	<u>3,350</u> psi	Main Member dowel bearing strength
F _{es} :	<u>21,000</u> psi	Side Member dowel bearing strength
l _m :	<u>1.6875</u> in	Main Member dowel bearing length
l _s :	<u>0.0625</u> in	Side Member dowel bearing length
R _d :	<u>2.2</u>	Reduction term - Table 12.3.1B (NDS)
R _e :	<u>0.1595</u>	= F _{em} /F _{es}
R _t :	<u>27.0</u>	= l _m /l _s
k ₁ :	<u>1.713</u>	See Table
k ₂ :	<u>0.561</u>	See Table

Reference Lateral Design Values - Table 12.3.1A (NDS)

$$Z_{Im}: \quad \underline{290} \text{ lbs} \quad Z_{Im} = \frac{D l_m F_{em}}{R_d} \text{ (EQ 12.3 - 1)}$$


$$Z_{II}: \quad \underline{116} \text{ lbs} \quad Z_{II} = \frac{k_1 D l_s F_{es}}{R_d} \text{ (EQ 12.3 - 3)}$$

$$Z_{III}: \quad \underline{123} \text{ lbs} \quad Z_{III} = \frac{k_2 D l_m F_{em}}{(1 + 2R_e) R_d} \text{ (EQ 12.3 - 4)}$$

$$Z_{IV}: \quad \underline{81} \text{ lbs} \quad Z_{IV} = \frac{D^2}{R_d} \sqrt{\frac{2F_{em}F_{yb}}{3(1 + R_e)}} \text{ (EQ 12.3 - 6)}$$

$$Z_{MIN}: \quad \underline{81} \text{ lbs}$$

Note: Side member is part of the Jeld-Wen assembly and verified during testing. Modes Z_{Is} and Z_{IIIs} are not applicable to the calculation.



Subject: Nail Lateral Design - Single Shear Cont.

Adjusted Lateral Design Values

$$Z' = Z * C_D * C_M * C_t * C_g * C_{\Delta} - \text{As per table 11.3.1 NDS}$$

C_D :	1.6	Load Duration Factor - Table 2.3.2 (NDS)
C_M :	1.0	Wet Service Factor - Table 11.3.3 (NDS)
C_t :	1.0	Temperature Factor - Table 11.3.4 (NDS)
C_g :	1.0	Group Action Factor - Section 11.3.6 (NDS)
C_{Δ} :	1.0	Geometry Factor - Section 12.5.1.1 (NDS)

$$Z': 129 \text{ lbs}$$

Fastener Bending Across Shim Space

Ω :	1.67	
L:	0.25	in Maximum Shim Gap
D:	0.113	in Diameter
F_{yb} :	100	ksi Dowel Bending Yield Strength

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16ZL}{\pi D^3} \Leftrightarrow Z = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

$$\text{Where } M = \frac{ZL}{2} \text{ (Guided Bending)}$$


$$Z_n/\Omega: 113 \text{ lbs}$$

Bearing on Masonry Strap

Ω :	3.00	
F_u :	33	ksi Tensile Strength of strap
t:	20	GA
t:	0.036	in thickness of strap
D:	0.113	in

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 4, AISI S100)$$

$$P_{nv}/\Omega: 120 \text{ lbs}$$



Subject: TEK Withdrawal

Input:
Calculation:

Shear Strength of Fastener - ESR 1976

Screw Size: 10-16

P_{nv}/Ω : 885 lbs See ESR 2196

Tensile Pullout - ESR 1976

Screw Size: 10-16

F_u : 45 ksi Tensile Strength of material NOT in contact with screw head

t: 16 GA

t: 0.0598 in Thickness of material NOT in contact with screw head

P_{nv}/Ω : 145 lbs See ESR 2196

Tensile Pullover

Note: The tensile pullover analysis checks the material IN contact with the screw head. This material is part of the Jeld-Wen assembly and has been verified by testing. Below is a check to ensure the head size of the TEK screw is equal to or larger than the head of the tested fastener, ensuring compliance.

Tested Fastener Head Size:

Screw Size: 8


Head Size: 0.312 in

Tested fastener is a

TEK Screw Head Size:

Screw Size: 10-16

Head Size: 0.365 in



Subject: TEK Lateral Design

Input:
Calculation:

Shear Strength of Fastener - ESR 1976

Screw Size: 10-16

P_{nv}/Ω : 573 lbs See ESR 2196

Bearing Strength of Material NOT in Contact with Screw Head - AISI S100

Screw Size: 10-16

Ω : 3.00

D: 0.138 in Root Diameter of TEK Screw
 F_u : 45 ksi Tensile Strength of material NOT in contact with screw head
t: 18 GA
t: 0.0478 in Thickness of material NOT in contact with screw head

$$\frac{P_{nv1}}{\Omega} = 2.7 * t * D * F_u - (EQ.J4.3.1 - 3, AISI S100)$$

$$\frac{P_{nv2}}{\Omega} = 4.2 \sqrt{t^3 * D} * F_u - (EQ.J4.3.1 - 1, AISI S100)$$

P_{nv1}/Ω : 267 lbs

P_{nv2}/Ω : 245 lbs

P_{nv}/Ω : 245 lbs $\frac{P_{nv}}{\Omega} = \text{smallest of } \frac{P_{nv1}}{\Omega} \text{ and } \frac{P_{nv2}}{\Omega}$

Bearing Strength of Material IN in Contact with Screw Head

Note: Material IN contact with the screw head is part of the Jeld-Wen assembly and has been verified by testing.

Fastener Bending Across Shim Space


L: 0.25 in Maximum Shim Gap
D: 0.138 in Root Diameter of TEK Screw
 F_{yb} : 100 ksi Yield Strength of TEK Screw

Ω : 3.00

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16P_n L}{\pi D^3} \Leftrightarrow P_n = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

Where $M = \frac{P_n L}{2}$ (Guided Bending)

P_n/Ω : 206 lbs



Bearing Strength of Masonry Straps - AISI S100

Screw Size: 10-16

TEK Screw

Ω : 3.00

D: 0.138 in

Root Diameter of TEK Screw

F_u : 33 ksi

Tensile Strength of Masonry Strap


t: 20 GA

t: 0.0359 in

Thickness of Masonry Strap

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ.J4.3.1 - 3, AISI S100)$$

P_{nv}/Ω : 147 lbs



Subject: Tapcon Lateral Design

Input:
Calculation:

Tapcon Size:

Size:
D: in Nominal Diameter
D_{sh}: in Shank Diameter

Fastener Shear Capacity - 3,000 psi Concrete

P_{nv}/Ω: lbs See Table 1B of NOA 24-0102.06

Fastener Shear Capacity - Medium-Weight CMU

P_{nv}/Ω: lbs See Table 3 of NOA 24-0102.06

Note:

- Critical anchor spacing is 16D
- Minimum Anchor Embedment is 1-1/4"
- Minimum Edge Distance is 2-1/4"

Fastener Bending Across Shim Space

L: in Maximum Shim Gap
D_{sh}: in Shank Diameter of Tapcon
F_{yb}: ksi Yield Strength of Tapcon

Ω:

$$\frac{F_{yb}}{\Omega} = \frac{M}{S} = \frac{16P_n L}{\pi D^3} \Leftrightarrow P_n = \frac{F_{yb} \pi D^3}{16 \Omega L}$$

Where $M = \frac{P_n L}{2}$ (Guided Bending)

P_n/Ω: lbs

Bearing Strength of Masonry Straps - AISI S100

Size: Tapcon Size
D_{sh}: in Shank Diameter of Tapcon Screw
F_u: ksi Tensile Strength of Masonry Strap
t: GA
t: in Thickness of Masonry Strap

Ω:

$$\frac{P_{nv}}{\Omega} = 2.7 * t * D * F_u - (EQ. J4.3.1 - 3, AISI S100)$$

P_{nv}/Ω: lbs