

Product Evaluation Report**Report No.:** FL-21361.5**Date:** October 6, 2020

Product Category	Sub Category	Manufacturer	Product Name
Sky Lights	Skylight	Natural Light Energy Systems 10821 N. 23rd Ave. Phoenix, AZ 85029 (602) 485-5984	Tubular Skylight "TS" Model "Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Natural Light Energy Systems, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 7th Edition (2020) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. When used in areas requiring wind borne debris protection, this product complies with FBC Section 1609.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Section 1609.1.2.2.
3. All roofing details shall comply with Chapter 15 of the FBC.
4. Site conditions that deviate from the details of drawing FL-21361.5 require further engineering analysis by a licensed engineer or registered architect.
5. See drawing FL-21361.5 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|--|--|---|
| 1. Test Report No.
TEL 01310309
TEL 01310309-IC
ATI 84497.01-106-31 | Test Standard
AAMA/WDMA/CSA 101/I.S.2/A440-08
ASTM E 1886(05)/1996(05)
ASTM D 635-06
ASTM D 1929-96
ASTM D 2843-99 | Testing Laboratory
Testing Evaluation Laboratory
Testing Evaluation Laboratory
Architectural Testing, Inc. | Signed by
V.K. Wright
V.K. Wright
Todd D. Borroughs |
| 2. Drawing No.
No. FL-21361.5 | Prepared by
RW Building Consultants, Inc. (#9813) | Signed & Sealed by
Lyndon F. Schmidt, P.E. | |
| 3. Calculations
Anchoring | Prepared by
RW Building Consultants, Inc. (#9813) | Signed & Sealed by
Lyndon F. Schmidt, P.E. | |
| 4. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Natural Light Energy Systems is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |



Lyndon F. Schmidt, P.E.
FL PE No. 43409
10/6/2020