

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 21376

Date: 09/22/2026

Detailed Product Description:


Manufacturer: PDQ MANUFACTURING

Manufacturer Address: 2754 CREEK HILL ROAD LEOLA, PA 17540

Model Name: SERIES 'GT', 'XGT', 'MR' & '6200' LOCKS/EXIT DEVICE

Maximum Load: +80 PSF, -80 PSF (Large Missile Impact)

Installation Drawings # 16-07

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
Comparative analysis used ☐ Yes ☒ No					
Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E330 & TAS 202	Uniform Static Air Press.	Architectural Testing, Inc	09/29/2016 12/07/2016	G1741.01-109-18 G1741.02-109-18	Charles Anderson, P.E. Charles Anderson, P.E.
AAMA 1304	Forced Entry	Architectural Testing, Inc	09/29/2016 12/07/2016	G1741.01-109-18 G1741.02-109-18	Charles Anderson, P.E. Charles Anderson, P.E.
Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 (TAS 201 & 203)	Large Missile Impact & Cyclic	Architectural Testing, Inc	09/29/2016 12/07/2016	G1741.01-109-18 G1741.02-109-18	Charles Anderson, P.E. Charles Anderson, P.E.
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.					
Evaluation Report Engineer:					
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538		 Sealed: 9/22/2026	