

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: WTG-200 ALUMINUM COMPOSITE METAL PANEL SYSTEM

MANUFACTURER: WEST TAMPA GLASS COMPANY
2705 N. 35TH STREET
TAMPA, FL 33605

To all concerned,

The WTG-200 Aluminum Composite Metal Panel System, manufactured by West Tampa Glass Company, is a Composite Metal panel System supported by extrusions at the panel edges which are mechanically fastened to the structure thru aluminum girts. The system has been tested per TAS 201, TAS 202, and TAS 203 by Intertek-ATI, with results shown in test reports D3711.01-401-18-R1 and F1912.01-401-18.

Technical Documentation:

1. Drawing "WTG-200 ACM PANELS" dated 6/7/24, signed and sealed by Scott Wolters, PE.
2. Test report listed above by Intertek-ATI, Inc. signed and sealed by J.P. McDonald, PE.
3. Supplemental Calculations to support WTG-200 ACM PANELS, signed & sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all the requirements of the 8th Edition (2023) Florida Building Code generally, and chapters 14,16, and 20 specifically, including the HVHZ provisions.


Limitations: This Aluminum Composite Metal Panel System is large missile (Levels D and E) and small missile impact resistant. It is approved for use inside and outside of the HVHZ, shutters are not required.


<u>Overall Dimensions:</u>	Maximum Panel Width:	192"
	Maximum Panel Height:	60"
	Maximum Design Pressure:	+/- 125 psf

The system is further limited as noted in drawing "WTG-200 ACM PANELS"

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
AUG 29 2024



SPECIALIZING IN MIAMI-DADE AND FLORIDA PRODUCT APPROVALS FOR ROOFING & GLAZING PRODUCTS