

Engineering Evaluation Report - #1630NI-06082026

Prepared by:

A. Lynn Miller, P.E.
3400 Precision Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: 29296

Manufacturer:

MI Windows and Doors
650 West Market Street
Gratz, PA 17030
(717) 365-3300

Product Description:

Series 1630 HS Vinyl Horizontal Sliding Window – Non-Impact Resistant – FL 21638

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number 1630HS-NI, signed and sealed by A. Lynn Miller, P.E.

Anchor Calculations signed and sealed by A. Lynn Miller, P.E., dated 06/08/26.

Test Reports:

Report No.: H3121.01-801-44, H2946.01-801-44, H2947.01-801-44, G2937.01-109-47, G2922.01-109-47,
H0451.01-109-47, Intertek/Architectural Testing, Inc. York, PA
Report No.: 1405.05-106-11, 2385.03-106-12, 2276.02-106-12, 2343.02-106-12-R1, Molimo, LLC, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440 2011/17

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-24, refer to approval document for glazing details.
- This product is NOT rated to be used in the HVHZ.
- This product is NOT impact resistant and does require impact protection in wind borne debris regions.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.

Certification of Independence:

A. Lynn Miller, P.E., is employed by MITER Brands and therefore has a financial interest in the company or any company manufacturing or distributing products for which this report is being issued, but does not, nor will acquire a financial interest in any other entity involved in the approval process of this product.

