L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Road Lewisville, NC 27023 434-688-0609 Rllomas@lrlomaspe.com

Report No.: 513792

Manufacturer: Eastern Architectural System

16341 Domestic Ave. Fort Meyers, FL 33912

Product Line: 176 HVHZ Vertical/Horizontal Mullion, Large and Small Missile Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02952 prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: NCTL 210-4032-01 signed and sealed by Gerard J. Ferrara, P.E.

National Certified Testing Laboratories, York, PA

TAS 201-94 Large Missile Impact Test, Level D, Wind Zone 4, Mullion impacted with #2 SYP 2x4, 96 1/2"

long, 9lbs at 50 ft/sec.

TAS 202 -94 Uniform Static Air Pressure, ±48.0psf design pressure, 16.5psf water penetration.

TAS 203-94 Cyclic Pressure loading ±48.0psf design pressure

3. Mullion analysis with Anchor calculations, report number 513792-1, per AAMA 450-10 option 1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


Maximum design pressure: Refer to charts in approval document

Maximum mullion height: 120"Maximum single fenestration width: 72"

- This are dust is not all to be used in the LIVIL
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Mullion material to be extruded Aluminum 6063-T6.
- Clip material to be extruded Aluminum 6063-T6.
- Fenestration units attached to mullion must have their own separate approval.
- Vertical units may be mulled indefinitely as long as maximum unit size is not exceeded.
- Design pressure of mulled units shall be controlled by the lesser design pressure of the assembly components; the mullion or the individual units.

Installation: Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-02952.

Certification of Independence: Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 02/02/2017