



NEMO|etc.

Certificate of Authorization #32455
353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

EVALUATE

TEST

CONSULT

P.E. EVALUATION REPORT (PEER)

CertainTeed, LLC

20 Moores Road
Malvern, PA 19355
(610) 893-5400

PEER-CTR-010.A.R7

FL21841-R7 (NON-HVHZ)

Date of Issuance: 02/10/2017

Revision 7: 09/26/2023

SCOPE:

This P.E. Evaluation Report (henceforth 'PEER') is issued under **F.A.C. Rule 61G20-3** and the applicable rules and regulations governing the use of construction materials in the State of Florida. The documentation submitted has been reviewed by Robert Nieminen, P.E. for use of the product under the Florida Building Code. The products described herein have been evaluated for compliance with the **8th Edition (2023) Florida Building Code sections noted herein.**

DESCRIPTION: RoofRunner™ and DiamondDeck®

LABELING: Labeling shall be in accordance with the requirements of the Accredited Quality Assurance Agency noted herein and **FBC 1507.1.1**.
CONTINUED COMPLIANCE: This PEER is valid until such time as the named product(s) changes, the referenced Quality Assurance or production facility location(s) changes, or Code provisions that relate to the product(s) change. Acceptance of our PEERs by the named client constitutes agreement to notify NEMO ETC, LLC of any changes to the product(s), the Quality Assurance or the production facility location(s). NEMO ETC, LLC requires a complete review of its PEER relative to updated Code requirements with each Code Cycle.

ADVERTISEMENT: The Florida Product Approval Number (FL#) preceded by the words "NEMO P.E. Evaluated" may be displayed in advertising literature. If any portion of the PEER is displayed, then it shall be done in its entirety.

INSPECTION: Upon request, a copy of this entire PEER shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This PEER consists of pages 1 through 4.


Prepared by:

**Digitally signed by
Robert Nieminen
Date: 2023.10.03
'08:14:43 -04'00**

This item has been digitally signed and sealed by Robert Nieminen, P.E.

Printed copies of this document are not considered signed and sealed, and the signature must be verified on any electronic copies.

Robert Nieminen, Florida P.E. 59166, FBC ANE1983
NEMO ETC, LLC, Florida CA #32455



CERTIFICATION OF INDEPENDENCE:

1. NEMO ETC, LLC does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products it evaluates.
2. NEMO ETC, LLC is not owned, operated or controlled by any company manufacturing or distributing products it evaluates.
3. Robert Nieminen, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the PEERs are being issued.
4. Robert Nieminen, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.
5. This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance unless retained specifically for that purpose.

© 2019 NEMO ETC, LLC

ROOFING COMPONENT EVALUATION:
1. SCOPE:

Product Category: Roofing
Sub-Category: Underlayment
Product Approval Method: Method 1, Option D – Codified Material, Evaluation by Engineer
Compliance Statement: RoofRunner™ and DiamondDeck®, as produced by CertainTeed, LLC, have demonstrated compliance with the following sections of the 8th Edition (2023) Florida Building Code through testing in accordance with the following Standards. Compliance is subject to the [Installation Requirements](#) and [Limitations of Use](#) set forth herein.

2. STANDARDS:

CODE SECTION	PROPERTY	STANDARD	YEAR
1507.1.1 / R905.1.1	Material standard	ASTM D8257	2020
1523.6.5.2.9	Rupture (pull-through)	TAS 117(B)	1995
TAS 110	Accelerated Weathering	ASTM D4798	2011

3. REFERENCES:

ENTITY	EXAMINATION	REFERENCE	DATE
NEMO (TST6049)	TAS 117(B)	4i-CTR-19-SSCRT-01.A	04/10/2019
NEMO (TST6049)	ASTM D4798	4j-CTR-20-SSUDL-02.A	12/16/2020
QAI (TST9808)	ASTM D8257	RJ8299P-10	02/15/2022
QAI (TST9808)	ASTM D8257	RJ8299P-13	03/29/2022
QAI (QUA7628)	Traceability/Inspections	Inspection Report	05/12/2020
QAI (QUA7628)	Quality Control	Florida BCIS	Current

4. PRODUCT DESCRIPTION:

TABLE 1: EVALUATED UNDERLAYMENTS			
PRODUCT	MATERIAL STANDARD	PLANT(S)	DESCRIPTION
RoofRunner™	ASTM D8257 ¹	Parzai, India	scrim-reinforced, polymer-based roof underlayment; nominal 2.25 lbs/square
DiamondDeck®	ASTM D8257 ¹	Parzai, India	scrim-reinforced, polymer-based roof underlayment; nominal 3.80 lbs/square

5. LIMITATIONS:

- 5.1 This is a building code evaluation. Neither NEMO ETC, LLC nor Robert Nieminen, P.E. are, in any way, the Designer of Record for any project on which this PEER, or previous versions thereof, is/was used for permitting or design guidance. PEERs are not to be construed as representing any attributes not specifically listed, nor are PEERs to be construed as an endorsement of the subject, or a recommendation for its use. There is no warranty by NEMO ETC, LLC or Robert Nieminen, P.E., express or implied, as to any finding or other matter in this PEER, or as to any product covered by the PEER.
- 5.2 This PEER is not for use in FBC High Velocity Hurricane Zone jurisdictions, as defined in FBC Chapter 2 (Broward and Miami-Dade Counties).
- 5.3 This PEER pertains to above-deck roof components. Roof decks and structural members shall be in accordance with FBC requirements to the satisfaction of the Authority Having Jurisdiction.

¹ Agreement between purchaser and seller, as set forth in Section 4.3, Note 1 of ASTM D8257-20, should be established as to slip resistance of RoofRunner and DiamondDeck.

- 5.4 This PEER does not include evaluation of fire classification. Refer to **FBC 1505** for requirements and limitations regarding roof assembly fire classification. Refer to **FBC 2603** for requirements and limitations concerning the use of foam plastic insulation.
- 5.5 **RoofRunner™** or **DiamondDeck®** may be used with any prepared roof cover where the product is specifically referenced within FBC approval documents. If not listed, a request may be made to the Authority Having Jurisdiction for approval based on this evaluation combined with supporting data for the prepared roof covering.

5.6 Allowable Roof Covers:

TABLE 2: ROOF COVER OPTIONS					
<u>FBC NON-HVHZ:</u>	1507.2	1507.3	1507.4 & 1507.5	1507.7	1507.8 & 1507.9
UNDERLAYMENT	ASPHALT SHINGLES	CLAY AND CONCRETE TILE	METAL PANELS OR SHINGLES	SLATE OR SLATE-TYPE SHINGLES	WOOD SHINGLES OR SHAKES
RoofRunner™	Yes	No	No	No	No
DiamondDeck®	Yes	No	Yes	Yes	No

5.7 Attachment Limitations:

Refer to [Section 6](#).

5.8 Exposure Limitations:

TABLE 3: EXPOSURE LIMITATIONS	
UNDERLAYMENT	MAXIMUM EXPOSURE (DAYS)
RoofRunner™	10
DiamondDeck®	180

6. INSTALLATION:

- 6.1 **RoofRunner™** and **DiamondDeck®** shall be installed in accordance with **CertainTeed** installation instructions subject to the [Limitations of Use](#) herein and the specifics noted below.
- 6.2 Re-fasten any loose decking panels, and check for protruding nail heads. Sweep the substrate thoroughly to remove any dust and debris prior to application, and prime the substrate (if applicable).
- 6.3 Consult CertainTeed published recommendations for the installation of CertainTeed WinterGuard (FL11288), or equal holding [Florida Statewide Product Approval](#) at vulnerable leak areas.

6.4 **RoofRunner™:**

- 6.4.1 Shall be installed in compliance with requirements for a synthetic underlayment (ASTM D8257) in **FBC 1507.1.1.1** or **FBC Residential R905.1.1.1** for the type of prepared roof covering to be installed, and the manufacturer's installation instructions. With the exception of Section 6.4.3 herein, FBC requirements take precedence over the manufacturer's installation instructions.
- 6.4.2 Fasteners:
Minimum fasteners shall be corrosion resistant, ring-shank cap nails shall be as set forth in **FBC 1507.1.1.1** or **FBC Residential R905.1.1.1**.

6.4.3 Attachment: Minimum attachment is noted in Table 4.

Note: These patterns have been determined through testing and analysis as meeting the intent of those set forth in **FBC 1507.1.1.1** or **FBC Residential R905.1.1.1**. Acceptance of this alternate attachment pattern is at the discretion of the Authority Having Jurisdiction, in advance of roof cover installation.

TABLE 4: MINIMUM ATTACHMENT FOR ROOFRUNNER™		
METAL CAP NAILS	PLASTIC CAP NAILS	BATTENS
At the circular target pattern (☉), which translates to 15-inch o.c. vertically and 12-inch o.c. horizontally. On vertical end-laps install 8 fasteners equally spaced 6-inch o.c. centered in the lap.	Max. 6-inch o.c. at the min. 3-inch horizontal side laps. At the circular target pattern (☉) in the field of the sheet, which translates to 15-inch o.c. vertically and 12-inch o.c. horizontally. On vertical end-laps install 8 fasteners equally spaced 6-inch o.c. centered in the lap.	When batten systems are to be installed atop the underlayment, the underlayment need only be attached at horizontal side-laps and vertical end-laps prior to batten installation

6.5 DiamondDeck®

6.5.1 Shall be installed in compliance with requirements for a synthetic underlayment (ASTM D8257) in **FBC 1507.1.1.1** or **FBC Residential R905.1.1.1** for the type of prepared roof covering to be installed, and the manufacturer's installation instructions. With the exception of Section 6.5.3 herein, FBC requirements take precedence over the manufacturer's installation instructions.

6.5.2 Fasteners:

Minimum fasteners shall be corrosion resistant, ring-shank cap nails shall be as set forth in **FBC 1507.1.1.1** or **FBC Residential R905.1.1.1**.

6.5.3 Attachment: Minimum attachment is noted in Table 5.

Note: These patterns have been determined through testing and analysis as meeting the intent of those set forth in **FBC 1507.1.1.1** and **R905.1.1.1**, regardless of whether plastic cap nails or metal cap nails are utilized. Acceptance of this alternate attachment pattern is at the discretion of the Authority Having Jurisdiction, in advance of roof cover installation.

TABLE 5: MINIMUM ATTACHMENT FOR DIAMONDECK®	
METAL OR PLASTIC CAP NAILS	BATTENS
At the diamond-printed pattern (◆), which translates to 15-inch o.c. vertically and 12-inch o.c. horizontally. On vertical end-laps install 8 fasteners equally spaced 6-inch o.c. centered in the lap.	When batten systems are to be installed atop the underlayment, the underlayment need only be attached at horizontal side-laps and vertical end-laps prior to batten installation

7. BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or Authority Having Jurisdiction to properly evaluate the installation of this product.

8. MANUFACTURING PLANTS:

Contact the named QA entity for manufacturing facilities covered by F.A.C. [Rule 61G20-3](#) QA requirements. Refer to [Section 4](#) herein for products and production locations having met codified material standards.

9. QUALITY ASSURANCE ENTITY:

[QAI Laboratories](#) – QUA7628; (604) 527-8378, mlansdowne@gai.org

- END OF PEER -