

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 21890

Date: 09/02/2026

Detailed Product Description:

Manufacturer: ES WINDOWS, LLC

Manufacturer Address: 3550 NW 49TH STREET MIAMI, FL 33142

Model Name: SERIES NS 25-PV ALUMINUM CURTAIN WALL SYSTEM

Maximum Load: +27.0 PSF, -27.0 PSF (Non-Impact)

Installation Drawings # W17-46

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

Mandatory Tests (Tested in accordance with AAMA 501/I.S.2/NAFS)


TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Fenestration Testing Lab, Inc.	10/25/2013	FTL-7489	Marlin D. Brinson, P.E.
ASTM E331 OR ASTM 547	Water Penetration	Fenestration Testing Lab, Inc.	10/25/2013	FTL-7489	Marlin D. Brinson, P.E.
ASTM E330	Uniform Static Air Press.	Fenestration Testing Lab, Inc.	10/25/2013	FTL-7489	Marlin D. Brinson, P.E.

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2026 Florida Building Code.

Evaluation Report Engineer:

Jalal Farooq
Al-Farooq Corporation

PE # 81223
EB # 3538



Sealed: 9/2/2026